



From: Anita Gardner

Sent: 23 January 2020 17:32

To: Adam Beamish 

Subject: R/224/19/PL - 4 Broadmark Parade, Rustington

Dear Mr Beamish,

I have received the following comments from the environmental health officer in respect of the above application:

I am in receipt of Ned Johnson Acoustic Consultants' Acoustic Assessment (ref.: 361920, dated December 2019) and whilst this appears satisfactory, it is not clear whether the attenuation measures as outlined in Ned Johnson Acoustic Consultants' Acoustic Assessment (ref. 451819 Rev. A, dated February 2019) have been completed. Before this Department can recommend discharge of this condition, please may the applicant confirm that the attenuation measures have been completed (these are summarised below for ease of reference):

- acoustic enclosures for fans
- fans attached to ducting using flexible connectors
- fans mounted on anti-vibration mounts
- in-line silencers installed to ducting
- acoustic enclosures for condenser units.

I would appreciate clarification within the next 7 days or the application will be refused and an enforcement file raised. It is apparent that the use of the development has commenced prior to test results, being submitted to and approved in writing by the local planning authority in breach of condition 5.

Regards
Anita Gardner



Anita Gardner | Principal Planner, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.