




Please treat as a substitute plan



Dear Anita,

Please find attached a revised foul drainage drawing as requested.

Kind regards

David

David Fuller BSc (Hons) MRICS
Partner



10 - 11 The Parade
Willowhayne Crescent
East Preston
West Sussex
BN16 1NS



This electronic message contains information that may be privileged and confidential. The information is intended to be for the use of the individual(s) named above. If you are not the intended recipient, please be aware that any disclosure, copying, distribution or use of the contents is prohibited. If you have received this message in error, please delete it and notify me immediately.

General Data Protection Regulations

In order to comply with the General Data Protection Regulations any personal information such as name, postal address, telephone number, and email address given will only be used to provide a requested service and will not be disclosed to any other third party without your prior permission or unless we are required to do so by law.



[REDACTED]

Dear David,

I haven't got to the position where I have had time to form a likely recommendation on the application, but given the 'No Objection' from the Parish Council the decision would be delegated to officer level.

In the meantime I note that the Drainage Engineer has made the following comments : It is assumed that the pool is open and not covered. If it is covered then it will need to be accounted for in the Surface Water Drainage Design. This has not been confirmed.

No information is given for how the pool will overflow and backwash. It is assumed that this will go to the foul sewer but this is not shown on the Foul Drainage Drawing. Southern Water will need to be consulted if this is the case. The foul drawing also shows the formally approved 2 bay garage which this application removes. The proposed 3 bay garage is not shown.

I note that you have provided a revised Surface Water Layout Plan, but would appreciate confirmation of the points raised by the Drainage Engineer so that it is clear whether Southern Water should be consulted.

I would also advise that I am still awaiting the comments of the Tree Officer.

Regards
Anita Gardner

[REDACTED]

[REDACTED]

Dear Anita,

I hope you're well.


Please could we discuss the above application at your earliest convenience. If you could please call me on [REDACTED]

Kind regards

David Fuller BSc (Hons) MRICS
Partner

<image001.png>

10 - 11 The Parade
Willowhayne Crescent
East Preston
West Sussex
BN16 1NS



This electronic message contains information that may be privileged and confidential. The information is intended to be for the use of the individual(s) named above. If you are not the intended recipient, please be aware that any disclosure, copying, distribution or use of the contents is prohibited. If you have received this message in error, please delete it and notify me immediately.

General Data Protection Regulations

In order to comply with the General Data Protection Regulations any personal information such as name, postal address, telephone number, and email address given will only be used to provide a requested service and will not be disclosed to any other third party without your prior permission or unless we are required to do so by law.

<image002.png>

<http://www.arun.gov.uk>
DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
