

scan

R/233/19/DOC



67 RODNEY ROAD
WALTON ON THAMES
SURREY
KT12 3LG

Mr Zac Denton
Arun District Council
The Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

27th September 2019

Dear Zac,

Re: R/164/19/L. Abbots Lodge Dental Practice, Rustington, BN16 3NL

Further to the granting of retrospective listed building consent for the alterations to the above dental practice I refer to condition 3.

The builder will be depositing at the council offices sections of timber to be used for the construction of the timber windows, along with this letter.

As discussed on site the style of the windows will be as the first floor window on the adjoining building and as the elevations submitted with the application.

The glazing will be slimline conservation double glazing of the 4mm-4mm-4mm arrangement. Consisting of 4mm clear toughened soft coat glass with a 4mm argon gas filled space and a further 4mm of glass. These will be bedded in seal fix and finished with a timber bead. All painted white.

I will forward details of the internal glazed screen door when I have them to hand.

If you require any further information please do not hesitate to contact me.

Yours sincerely,



Alan Tate - for and on behalf of Grey Associates.

Enc timber sections

WWW.GREYASSOCIATES.CO.UK