

From: Chima Umunnakwe <Chima.Umunnakwe@arun.gov.uk>
Sent: 20 October 2021 19:20
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: R/246/21/PL

Dear Planning,

I refer to the above application for planning consideration.

I have reviewed the submitted details, and I can advise that sufficient information has not been provided to address potential issues relating to noise and odour from the proposed scheme. The applicant has provided some statements relating to the points mentioned. However, I do not consider that the information before me demonstrates that the complaint will not arise due to the proposed extraction system.

Considering the proximity of flats in the location of the proposed extractor system, the applicant needs to carry a noise assessment based on the guidance found in BS4142 2014. Any odour neutralising mechanism should conform to the defunct guidance given by The Control of Noise and Odour from commercial kitchen exhaust system by DEFRA.

Once we have received the additional details, I will be happy to provide a revised consultation response.

I hope this helps.

Regards

Chima Umunnakwe
Environmental Protection Officer
Technical Services



T: 01903 737336
E: chima.umunnakwe@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Due to the current pandemic, work is being prioritised according to public safety risks and you may not receive an immediate response to your email. Wherever possible we will endeavour to respond within 7 working days.

The Environmental Health Team in particular are focused on supporting COVID-19 compliance, and other services may be limited or delayed. Further details of our current service levels can be found at: <https://www.arun.gov.uk/service-status>

If you are making contact for advice or to register a new request for service, including enquiries about COVID-19, food safety, noise or pollution, you can register these directly on-line at <https://eh.arun.gov.uk/>

