

Amber Willard

From: Lauren Willard <[REDACTED]>
Sent: 20 February 2018 18:39
To: Amber Willard
Subject: Re: R/257/17/CLP
Attachments: 1123.01.c Existing and Proposed A1.pdf

Follow Up Flag: Follow up
Flag Status: Flagged
Categories: Follow up

Dear Amber

Thank you for your email.

You are correct the annotation on the elevations should say the scale is 1:50 not 1:100. Please find attached the amended drawing.

Kind Regards

Lauren

From: Amber Willard
Date: Tuesday, 20 February 2018 16:33
To: Lauren Willard
Subject: R/257/17/CLP

Dear Mrs Willard

I am currently looking at your application R/257/17/CLP and I think there may be an error with one of the scales. The scale for the existing and proposed elevations on drawing number 1123.01.b is 1:100 however this would make the proposed extension over 6m high .

I feel as if 1:50 should be the correct scale and if this is the case please am I able to receive an amended plan showing this.

Thank-you

Amber Willard

[REDACTED]