

From: Kate Giddings <kate.giddings@arun.gov.uk>
Sent: 23 January 2020 16:33
To: Anita Gardner <Anita.Gardner@arun.gov.uk>
Cc: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: R/295/19/DOC - 4 Broadmark Parade, Rustington, BN16 2NE

Hi Anita,

In relation to the above application, I am in receipt of Ned Johnson Acoustic Consultants' Acoustic Assessment (ref.: 361920, dated December 2019) and whilst this appears satisfactory, it is not clear whether the attenuation measures as outlined in Ned Johnson Acoustic Consultants' Acoustic Assessment (ref. 451819 Rev. A, dated February 2019) have been completed. Before this Department can recommend discharge of this condition, please may the applicant confirm that the attenuation measures have been completed (these are summarised below for ease of reference):

- acoustic enclosures for fans
- fans attached to ducting using flexible connectors
- fans mounted on anti-vibration mounts
- in-line silencers installed to ducting
- acoustic enclosures for condenser units.

I also understand that the latter part of condition 5 states that the use of the development shall not commence until test results, demonstrating the minimum sound insulation criteria have been achieved, has been submitted to and approved in writing by the local planning authority, however I have recently been informed that the premises is already trading and has been doing so for a number of weeks.

Many thanks,

Kate.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF
Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.