

Sylvia Rowbotham

From: Laura Gibbon
Sent: 23 January 2019 09:26
To: [REDACTED]
Cc: Michael Hartnett; Sylvia Rowbotham; Steve Dalton
Subject: RE: ST MARYS CLOSE 2 DWELLINGS HURST ROAD; Surface Water Drainage- Soakaway Test Result

Hi Kazys,

Thank you for the updated information. If a formal application is submitted to planning with this information and including construction detail drawings I will be happy to recommend the discharge of the surface water drainage condition.

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

[REDACTED]
Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: kazys [REDACTED]
Sent: 21 January 2019 12:35
To: Laura Gibbons
Cc: Michael Hartnett; Sylvia Rowbotham; Steve Dalton
Subject: RE: ST MARYS CLOSE 2 DWELLINGS HURST ROAD; Surface Water Drainage- Soakaway Test Result

Laura

Further to your e-mail and our subsequent discussion I have re-calculated the proposed soakaways based on a 200mm topsoil strip above the stone fill. This gives a revised soakaway length of 10.6m. Attached are the substantiating calculations and a copy of the revised drawing, As discussed we specify a stone fill of 0.4 porosity based on information supplied to us by the aggregate supplier. I have attached information regarding this.
I trust you will now be in a position to approve the drainage design. It would be helpful if you could advise your planning Colleague accordingly but I can confirm that our client will be making a formal application to discharge the appropriate. planning conditions.
Many thanks

Regards

Kazys