

Anita Gardner

From: Bruce Taunton
Sent: 02 July 2012 17:04
To: Anita Gardner
Subject: RE: R/99/12 Amendments to existing dwelling and new boundary walling - 1 Botany Close, Rustington

Hi Anita,

My apologies for not responding sooner. With regards to the proposed wall design calculation, although the allowable soil bearing capacity for the foundation design has been over assumed, the results are within normal tolerances and therefore considered acceptable.

Regards

Bruce Taunton

From: Anita Gardner
Sent: 02 July 2012 14:48
To: Bruce Taunton
Subject: FW: R/99/12 Amendments to existing dwelling and new boundary walling - 1 Botany Close, Rustington

Bruce,
Please can you provide me with a response to the e-mail below as soon as possible
Thanks
Anita

From: Anita Gardner
Sent: 19 June 2012 11:22
To: Bruce Taunton
Subject: FW: R/99/12 Amendments to existing dwelling and new boundary walling - 1 Botany Close, Rustington

Bruce,
Please can you advise if the attached structural calculations are satisfactory for the proposed boundary walling which abuts a greensward used by the public. If you need to look at the plans you can borrow the file if necessary, reference R/99/12.
At this stage I can't get the attached information scanned since it isn't printable from our system so I have requested a hard copy.
Thanks
Anita

From: Oliver Brown [REDACTED]
Sent: 18 June 2012 16:46
To: Anita Gardner
Subject: Re: R/99/12 Amendments to existing dwelling and new boundary walling - 1 Botany Close, Rustington

Dear Ms Gardner,

Further to our recent correspondence please see attached structural calculations for the new boundary wall to the east and southern boundaries.

I trust this will be sufficient but if there are any queries or you require any further information prior to approval please do let me know.

Kind regards

Oliver Brown