

**From:** Martyn White  
**Sent:** 18 January 2019 11:54  
**To:** Planning.Responses  
**Cc:** Zac Denton  
**Subject:** WA/105/18/L

WA/105/18/L

The proposal is to replace 6 wooden windows to the front of the property. It is argued that they are beyond repair, and evidence is provided to support such a claim. Further a drawing and a picture is provided which identifies how the window will look. The windows appear to be a copy of both the existing, and neighbouring windows. Such a proposal can therefore be supported as it will not harm the significance of the building.

It is not clear however, if the windows will be single or double glazed. This should be confirmed. You may also wish to have information related to measurements of the proposed windows in order to ensure that they are direct copies of the existing ones.

Martyn White | Principal Conservation Officer, Planning Policy, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF  
Internal: 37717 | External: +44 (0) 1903 737717 | E-mail: Martyn.white@arun.gov.uk

Visit Arun's web site at [www.arun.gov.uk](http://www.arun.gov.uk)



Save the environment - think before you print.