

- ### DRAINAGE NOTES

- DRAFT



Date	Drawing No.	Rev
March 2018	2017-D1377-007	-



REFER TO DRAWING 2017-D1377-001
'ENGINEERING LAYOUT - DRAINAGE,
LEVELS AND CONTOURS' FOR
LOCATION AND ARRANGEMENT.

PARALLEL TRENCHES TO BE POSITIONED
WITH A MIN 1000mm GAP.

**TO BE INSTALLED TO
COMPLY WITH BS6297:2007 +
A1:2008 'CODE OF PRACTICE
FOR THE DESIGN AND
INSTALLATION OF DRAINAGE
FIELDS FOR USE IN
WASTEWATER TREATMENT'**

FOR GRAVITY FLOW SYSTEMS FROM A SMALL NUMBER OF HOUSES, THE MAXIMUM LENGTH OF A SINGLE TRENCH SHOULD BE NO MORE THAN 30M BECAUSE OF THE INCREASED RISK OF POOR DISTRIBUTION WITHIN LONGER TRENCHES

It is assumed that all works will be carried out by a competent contractor working, where appropriate, to an approved risk assessment and method statement



incoming 100mmØ uPVC SPINE to BS4660 for Drainage
Field 1 (serving Plots 5 and 6)