

From: Martyn White <Martyn.White@arun.gov.uk>
Sent: 21 December 2021 17:15
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: WA/120/21/DOC

WA/120/21/DOC

Days, Days Lane Aldingbourne BN18 0TA

Approval of details reserved by condition imposed under WA/55/21/L relating to conditions 3-sample panel of flint work & 4-details of landscape works.

Whilst reviewing the plans submitted as part of this discharge of condition application, I have noticed that they appear different from those provided as part of the approved application. The retaining wall is not to the design of the approved plans in that it is now reduced in width and a small planter has been constructed in an area where the wall should have extended to. I also note an additional section of flint walling and altered landscape proposals (i.e. the level path is now wider).

However, the flintwork quality and landscaping materials all seem to be acceptable.

Martyn White
Principal Conservation Officer,
Planning Services



Please note: I work on Conservation for half of the working Week (all day Monday and Friday and Tuesday Afternoons)

T: 01903 737717

E: Martyn.White@arun.gov.uk or Conservation.officer@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

To register to receive notification of planning applications in your area p



<https://www1.arun.gov.uk/planning-application-finder>