

G6386 Wandleys Farm, Fontwell
Soakage Testing (Second Round)

TP102 Test 1

Test Start Date: 03-Mar-20

Dimensions (m):


width = 0.30

length = 0.30

depth = 0.50

Date	Time	Date and time	Elapsed	Dip	End Fit
03/03/2020	14:50	03/03/2020 14:50	start	530	
03/03/2020	14:56	03/03/2020 14:56	0	95	
03/03/2020	15:01	03/03/2020 15:01	5	105	
03/03/2020	15:09	03/03/2020 15:09	13	125	
03/03/2020	15:27	03/03/2020 15:27	31	145	
03/03/2020	16:18	03/03/2020 16:18	82	210	
03/03/2020	18:00	03/03/2020 18:00	184	310	
03/03/2020	21:10	03/03/2020 21:10	374	420	
04/03/2020	07:30	04/03/2020 07:30	994	545	
04/03/2020	15:00	04/03/2020 15:00	1444	545	

hole dry
rain, hole dry



	Time (mins)	
t0	95	
t25	207.5	70
t50	320	
t75	432.5	430
t100	545	
fall		0.45
t25 - t75		0.225
Area t50		0.306

Infiltration Coefficient = 3.06E-06 m/s

Infiltration Coefficient = 3.13E-06 m/s

