

[REDACTED]

From: Amanda Scholes on behalf of Planning.Responses
Sent: 16 October 2019 08:30
To: Planning Scanning
Subject: FW: White Cottage, Walberton (WA/22/19/PL)

From: Andrew Wood <[REDACTED]>
Sent: 15 October 2019 16:12
To: Planning.Responses <[REDACTED]>
Subject: FW: White Cottage, Walberton (WA/22/19/PL)

Consultee response

From: Laura Gibbons <[REDACTED]>
Sent: 15 October 2019 16:03
To: Andrew Wood <[REDACTED]>
Subject: RE: White Cottage, Walberton (WA/22/19/PL)

Hi Andrew,

Yes, should be. But it is unlikely that I will get time to review this prior to my departure, but hopefully one of my colleagues will be able to pick it up.

Thanks,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

[REDACTED] [\[REDACTED\]@arun.gov.uk](mailto:[REDACTED]@arun.gov.uk)
Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Andrew Wood <[REDACTED]>
Sent: 15 October 2019 16:00
To: Laura Gibbons <[REDACTED]>
Subject: RE: White Cottage, Walberton (WA/22/19/PL)

Are these the final details required Laura?

Thanks btw!



From: Laura Gibbons [REDACTED]
Sent: 15 October 2019 15:53
To: Julia Davies [REDACTED]; Andrew Wood [REDACTED]
Subject: RE: White Cottage, Walberton (WA/22/19/PL)

Hi Julia,

The infiltration test was completed at shallower depths than the proposed infiltrating structures, as a result we require a Factor of Safety of 3 to be used in design.

Please can details of the pipe diameters and falls proposed be provided.

Please provide inspection chambers rather than easy bends.

Kind Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)



From: Julia Davies [REDACTED]
Sent: 14 October 2019 13:11
To: Andrew Wood [REDACTED]
Cc: Laura Gibbons [REDACTED]
Subject: White Cottage, walberton (WA/22/19/PL)

Dear Andrew

Following your telephone message earlier, please find attached some additional information relating to the surface water design for White Cottage. This relates to the test results from the groundwater monitoring and a site plan showing the location and construction of the soakaways.

A arboriculturist has been appointed and is in the process of compiling a tree report and protection methodology. As soon as this is issued I will pass it through to you.

Any queries, please give me a call.

With kind regards

