

From: Kate Giddings
Sent: 08 May 2019 15:43
To: Charlotte Easton
Cc: Planning.Responses; Anna Appleton
Subject: WA/23/19/DOC - Fairmead Farm Land, Binsted Lane, Arundel, BN18 0LQ

Good afternoon,

In relation to the above, the document supplied is not sufficient for this department to recommend discharge of condition 6 – external lighting.

For clarity, the condition requires details on the type of appliance, the height and position of fitting, illumination levels and light spillage. There should also be details regarding the potential impact to bats, however this is not something which can be assessed by this Department.

Many thanks,

Kate.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF

Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.