

From: Juan Baeza
Sent: 17 June 2019 14:18
To: [REDACTED]
Cc: Kate Giddings
Subject: FW: WA/23/19/DOC

Dear Ms Osborne

I am forwarding you the comments from my colleague in Environmental Health. Can you please address the points made by Ms Giddings. You may want to contact her separately before responding so as to achieve a positive outcome to any further details you submit.

Regards

Juan Baeza Area Team Leader – Planning Department, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37765 | External: +44 (0) 1903 737765 | E-mail: juan.baeza@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Kate Giddings
Sent: 17 June 2019 14:08
To: Juan Baeza
Subject: RE: WA/23/19/DOC

Dear Juan,

Thank you for your e-mail and apologies for the delayed reply; I have been out of the office. In relation to the above application, the condition states that the applicant must provide the following, not all of which has been submitted, therefore this Department cannot consider discharging the condition:

- type of appliance
- height of fixture
- position of fixture
- illumination levels
- light spillage

There is also a requirement to assess the impact to bats, although I am not sure who would have jurisdiction over this aspect.

Many thanks,

Kate.

PS – I'm off tomorrow but back in for the rest of the week.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF

Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Juan Baeza
Sent: 04 June 2019 11:51
To: Kate Giddings
Subject: FW: WA/23/19/DOC

Hi Kate

The applicant contacted me today. She has been trying to contact you as per my email (attached) to her without any luck. Essentially she is asking whether the details submitted with the application are sufficient.

I look forward to hearing back from you.

Thanks

Juan Baeza | Area Team Leader – Planning Department, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37765 | External: +44 (0) 1903 737765 | E-mail: juan.baeza@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Deborah Osborne
Sent: 04 June 2019 10:02

To: Juan Baeza
Subject: WA/23/19/DOC

Dear Mr Baeza,

Further to your email 31st May 2019 and our telephone conversation today regarding the objection of environmental health to the lighting details I confirm that the details of the light are on the data sheet provided in the application and the position and location of the light is marked on the plan.

Kind regards

Deborah Osborne