

John Hall Consulting Ltd
113 Limmer Lane
Felpham
PO22 7LR

Date: 27th May 2021

Please ask for: Mrs A Gardner

Tel: 01903 737529

Your Ref:

Our Ref: WA/24/21/DOC

Dear Mr Hall,

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Approval of details reserved by condition imposed under ref WA/62/20/PL relating to Condition Nos 3 - surface water drainage, 4 - discharge flows to watercourses, 5 - maintenance & management of surface water drainage, 6 - hard & soft landscaping, 7 - Construction Management Plan, 8 - ecology, 12 - cycle parking, 13 - archaeology, 16 - contamination and 17 - verification report.

Lower Farm Yapton Lane Walberton BN18 0AS

Notification regarding the above application:

Condition Number 3

Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

Decision:

Arun District Council have decided to **REFUSE details reserved by condition for the following reasons:**

The infiltration testing and groundwater monitoring is satisfactory, but it does not address the other comments made by the drainage engineer. In addition, flotation calculations will be required as a result

of the high groundwater. Based upon the groundwater being its highest at the beginning of the monitoring, monitoring commencing in late January, and levels close to surface it will need to be demonstrated that groundwater is assumed to be at surface level.

Please ensure that no construction is occurring prior to discharge of this condition..

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning