

John Hall Consulting Ltd
113 Limmer Lane
Felpham
PO22 7LR

Date: 27th May 2021

Please ask for: Mrs A Gardner

Tel: 01903 737529

Your Ref:

Our Ref: WA/24/21/DOC

Dear Mr Hall,

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Approval of details reserved by condition imposed under ref WA/62/20/PL relating to Condition Nos 3 - surface water drainage, 4 - discharge flows to watercourses, 5 - maintenance & management of surface water drainage, 6 - hard & soft landscaping, 7 - Construction Management Plan, 8 - ecology, 12 - cycle parking, 13 - archaeology, 16 - contamination and 17 - verification report.

Lower Farm Yapton Lane Walberton BN18 0AS

Notification regarding the above application:

Condition Number 5

Development shall not commence until full details of the maintenance and management of the surface water drainage system is set out in a site-specific maintenance manual and submitted to, and approved in writing, by the Local Planning Authority. The manual is to include details of financial management and arrangements for the replacement of major components at the end of the manufacturer's recommended design life. Upon completed construction of the surface water drainage system, the owner or management company shall strictly adhere to and implement the recommendations contained within the manual.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W DM1, W DM2 and W DM3 of the Arun Local Plan. It is considered necessary for this to be a pre-commencement condition to ensure that the future maintenance and funding arrangements for the surface water disposal scheme are agreed before construction commences.

Decision:

Arun District Council have decided to **REFUSE details reserved by condition for the following reasons:**

The infiltration testing and groundwater monitoring is satisfactory, but it does not address the other comments made by the drainage engineer. In addition, flotation calculations will be required as a result of the high groundwater. Based upon the groundwater being its highest at the beginning of the monitoring, monitoring commencing in late January, and levels close to surface it will need to be demonstrated that groundwater is assumed to be at surface level.

Please ensure that no construction is occurring prior to discharge of this condition..

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC', followed by a period.

Neil Crowther
Group Head of Planning