




From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 24 February 2022 16:18

To: Anita Gardner <Anita.Gardner@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Land West Of Yapton Lane Walberton - WA/2/22/OUT

Planning Application Reference: WA/2/22/OUT

Proposal: Outline planning application with all matters reserved, other than means of access, for the construction of up to 48 dwellings (30% affordable homes) and dental/doctors' surgery (Use Class E (e)). (This application may affect the setting of a listed building & may affect the Walberton Village Conservation Area).

Location: Land West Of Yapton Lane Walberton

Dear Anita,

Environmental Health has no objection to the above proposal, however the following matters must be considered

Contaminated Land

Prior to commencement of the development hereby approved (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved in writing by the Local Planning Authority:

1. A Preliminary Risk Assessment which has identified: all previous (historical) uses; potential contaminants associated with those uses; a conceptual model of the site indicating sources, pathways and receptors; potentially unacceptable risks arising from contamination at the site.
2. A Site Investigation Scheme, based on (1) above to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
3. Based on the Site Investigation Scheme and the detailed risk assessment (2), an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.

4. A Verification Report providing details of the data that will be collected in order to demonstrate that the works set out in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Note: Any changes to these components, (1) to (4) require the express written consent of the Local Planning Authority

The scheme shall be implemented as approved above and, prior to commencement of any construction work (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), a Verification Report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of that remediation shall be submitted to and approved in writing by the Local Planning Authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. The report shall also include a long-term monitoring and maintenance plan for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action, as identified in the verification report, and for the reporting of this in writing to the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

Unexpected contamination

If during development, any visible contaminated or odorous material, (for example, asbestos containing material, stained soil, petrol / diesel / solvent odour, underground tanks or associated pipework) not previously identified, is found to be present at the site, no further development (unless otherwise expressly agreed in writing with the Local Planning Authority) shall be carried out until it has been fully investigated using suitably qualified independent consultant(s). The Local Planning Authority must be informed immediately of the nature and degree of the contamination present and a method statement detailing how the unsuspected contamination shall be dealt with must be prepared and submitted to the Local Planning Authority for approval in writing before being implemented.

If no such contaminated material is identified during the development, a statement to this effect must be submitted in writing to the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

Construction hours

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

[In addition to these hours of working the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Internal Noise Levels – Residential units BS8233:2014

Prior to the commencement of the development hereby approved, a scheme to demonstrate that the internal noise levels within the residential units will conform to the 'Indoor ambient noise levels for dwellings' guideline values specified within Table 4 under section 7.7.2 of BS 8233:2014 and shall be complied by a competent acoustician on sound insulation and noise reduction for buildings and shall be submitted to and approved in writing by the Local Planning Authority. The scheme should take into account the correct number of air changes required for noise affected rooms. The works specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

External Noise Levels – Residential units BS8233:2014

Prior to the commencement of the development hereby approved, a scheme to demonstrate that the external noise levels within the curtilage of residential units will conform to the 'Design criteria for external noise' upper guideline value of 55 dB $L_{Aeq,T}$ as specified within section 7.7.3.2 of BS 8233:2014.

Guidance on sound insulation and noise reduction for proposed developments shall be submitted to and approved in writing by the Local Planning Authority. The work specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Air Quality Impact assessment

As this is a major application, consideration must be given to air quality issues. As per the National Planning Policy Framework (NPPF) (updated February 2019) air quality should be considered at the design stage and incorporate appropriate and effective mitigation.

The applicant must follow the Air Quality & Emissions Mitigation Guidance for Sussex (2013), available at: <http://www.sussex-air.net/Consultation/AirQualitydocument.pdf>

This countywide adopted guidance states that where a major sized development is proposed a number of checklists should be followed in order to determine the likely impact of the proposed development on air quality. The intention of the guidance is to identify any air quality impacts through an impact assessment and ensure the integration of appropriate mitigation into a scheme at the design stage, so the damage costs on health can be properly mitigated. The air quality impact assessment can follow the procedures contained within the Institute of Air Quality Management (IAQM) Guidance entitled: 'Land-Use Planning & Development Control: Planning For Air Quality' (January 2017), available at: <http://www.iaqm.co.uk/text/guidance/air-quality-planning-guidance.pdf>

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Electric Vehicle Charging Points

Prior to occupation of any of the dwellings, a scheme for the provision of facilities to enable the charging of electric vehicles to serve the approved development shall be submitted to the local planning authority for approval and thereafter implemented in accordance with the approved details and the charge points shall thereafter be retained and maintained in good working condition.

Reason: New petrol and diesel cars/vans will not be sold beyond 2030, and to mitigate against any potential adverse impact of the development on local air quality, in accordance with policy QE DM3 (c) of the Arun Local Plan, the Arun District Council Electric Vehicle Infrastructure Study (November 2017) and the National Planning Policy Framework (NPPF).

Commercial Noise Sources

No development shall commence until an acoustic assessment has been undertaken to determine the impact of noise from commercial related noise sources (including DM Chainsaws) on the proposed dwellings. The results of the assessment and details of a scheme of mitigation measures necessary to ensure an appropriate level of aural amenity within habitable rooms and amenity in garden areas shall be submitted and approved in writing by the Local Planning Authority. All works, which form part of the approved scheme, shall be completed before any part of the development is occupied and shall thereafter be maintained in accordance with the approved details.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

