

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter [here](#)



From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 30 May 2022 11:47
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: David Easton <David.Easton@arun.gov.uk>
Subject: WA/34/22/DOC

Dear David,

With regard to discharge of Condition 2 of WA/48/19/RES, please could the applicant confirm:

1. That 100% of the houses with a driveway or a garage have an active EV charging point.
2. That 30% of parking spaces for all other developments have an active EV charging point.
3. The specific numbers of parking spaces that 1 and 2 refer to (i.e. number of dwellings)
4. That the proposed EV charging points meet all the following requirements:
 - a. Be designed and installed as described in BS EN 61851.
 - b. Have a minimum nominal rated output of 7kW.
 - c. Be fitted with a universal socket (also known as an untethered electric vehicle charge point). Alternatively, in exceptional circumstances, such as for a self-build property, if the vehicle requirements are already known, a tethered electric vehicle charge point may be acceptable.
 - d. Be fitted with an indicator to show the equipment's charging status that uses lights, or a visual display.
 - e. Be a minimum of a Mode 3 specialised system for electric vehicle charging running from a dedicated circuit, or equivalent, as defined in BS EN IEC 61851-1.
 - f. The requirements of BS 7671.
 - g. The requirements in the IET's Code of Practice: Electric Vehicle Charging Equipment Installation.

Regards

Fiona Fitzgerald

Fiona Fitzgerald
Senior Environmental Health Officer
Environmental Health

T: 01903 737674

E: fiona.fitzgerald@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)

