

Siobhan Honney-Bayes

From: Brian Holland
Sent: 15 June 2011 12:43
To: Planning.Responses
Cc: Susan Leeson
Subject: RE: Planning Consultation on: WA/37/11/

Susan:

Apologies for late response.

Engineer's Drainage comments: It is noted the proposal for Surface Water disposal is via soakaway. Design of the soakaway should be based on BRE365 and submitted for approval prior to commencement of works on site.
 Note: Monitoring of water table levels over the winter period together with soil percolation tests will be required to enable the design to be carried out.

Regards

From: Stephen Daniels
Sent: 24 May 2011 17:00
To: Brian Holland
Subject: FW: Planning Consultation on: WA/37/11/

FYI

Stephen

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 24 May 2011 16:01
To: Stephen Daniels
Subject: Planning Consultation on: WA/37/11/

To: **Engineers (Fluvial Flooding)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO: WA/37/11/

Registered: 14-APR-11
Site Address: Land Adjacent to Walberton Village Hall The Street Walberton BN18 0PQ

Grid Reference: 497275 106026

Category: Plan Applicat'n

Description of Works: Single storey pre-school. Resubmission following WA/12/11.
 (This is a Departure from the Development Plan)

The Council have received the above planning application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 26-MAY-11. You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our

website.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs S Leeson who can be contacted on telephone number 01903 737769.

Thanking you in anticipation

Regards
Planning Case Officer

consultee_email
