

From: Roger Spencer <Roger.Spencer@arun.gov.uk>
Sent: 26 August 2020 09:34
To: Daun Johnson <Daun.Johnson@arun.gov.uk>
Subject: FW: WA/39/18/PL - Winter Ground Water Monitoring

D,

Please see the response from the Applicant, for the file.

Regards,

Roger Spencer
Engineering Services Manager, Place

T: 01903 737812
E: roger.spencer@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Catherine Henderson [REDACTED]
Sent: 26 August 2020 08:46
To: Roger Spencer <Roger.Spencer@arun.gov.uk>
Subject: Re: WA/39/18/PL - Winter Ground Water Monitoring

On Wed, Aug 26, 2020 at 8:42 AM Roger Spencer <Roger.Spencer@arun.gov.uk> wrote:

Thank you Roger, that is most helpful. If I need anything else I'll be in touch.

Kind regards
Cathy Henderson

Dear Catherine,

Thank you for contacting us regarding monitoring conditions, so that the drainage can be designed for your new build.

With just one unit, it will not be necessary for you to monitor throughout the winter but a couple of readings taken during the time when groundwater can be expected to be at its highest will be necessary. From this you will then be able

to undertake your infiltration/percolation testing. Doing this test without knowing the groundwater conditions would not be satisfactory, as the percolation has to occur above the groundwater; it (percolation testing) also has to be done in winter, to reflect

the soil conditions in the worst case scenario.

This may seem onerous for a single unit but the ground conditions in your area are variable, with the water table usually shallow, not giving much room for soakaway volume etc. Being in the Lidsey drainage catchment also has a bearing on

matter.

Please do not hesitate to contact us again should you want further advice.

Regards,

Roger Spencer

Engineering Services Manager,

Place



T:

01903 737812

E:

roger.spencer@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



Sign up to our newsletter

[here](#)

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from

<https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee),

please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent

those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council

reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage

caused. Any reference to "e-mail" in this disclaimer includes any attachments.
