



Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex BN17 5LF
Planning General Enquiries
Tel: (01903) 737756 Fax: (01903) 730442
Dx: 57406 Littlehampton
Minicom: 01903 732765
e-mail: planning@arun.gov.uk
website: www.arun.gov.uk/planning

Sussex Building Consultancy Limited
Sussex Building Consultancy Limited
3 Northcote Road
Bognor Regis
PO21 5LZ

Your Ref: WA/40/18/DOC

Please ask for:

Mr R Castro-Parker

09 August 2018

Dear Mr C Moore

Town & Country Planning Act 1990 (as amended)
Town and Country Planning (Development Management Procedure) (England) Order 2015
Application for approval of details reserved by condition imposed under condition No. 3 (materials & finishes for external walls & velux flat roof light) & 4 (proposed surface water drainage scheme)
Walberton Baptist Church The Street, Walberton,

Notification regarding the above application:

Condition Number 4

Development shall not commence until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority.

The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, the recommendations of the SUDS Manual produced by CIRIA.

Winter groundwater monitoring to establish highest annual ground water levels and Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage.

No building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason : To ensure that the proposed development is satisfactorily drained in accordance with policies GEN7 and GEN9 of the Arun District Council Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

Decision:

Arun District Council have decided to **APPROVE details reserved by this condition**
With regard to condition 4, having regard to the email from the Council's Engineer (Drainage and Coastal) date received 07/08/2018, I can confirm that the drainage details on submitted plan number 1784/SK2 are deemed acceptable .

Condition 4 is therefore fully discharged insofar as the submission of details relates and on the understanding that the scheme will be implemented in accordance with the approved details.

docdeci

Please do not hesitate to contact the above officer if you require any further assistance.

Yours sincerely

A handwritten signature in black ink, appearing to be 'NC' followed by a flourish and a period.

Neil Crowther
Group Head of Planning