



From: Matthew Kennett
Sent: 23 September 2014 14:43
To: Damian Sullivan; Planning.Responses
Subject: RE: Planning Consultation on: WA/48/14/PL

Environmental Health Advises;

Please apply conditions ENV 3, 5 and 6 (below) to any approval due to the potentially contaminative past use.

thanks

Matthew Kennett
Pollution Officer
Environmental Health
Arun District Council

01903 737696 (direct line)
Civic Centre, Maitravers Road, Littlehampton BN17 5LF
For further information on Environmental Health's services visit our website: www.arun.gov.uk/eh

ENV3 Universal condition for development on land affected by contamination

Environmental Health position

We consider that planning permission should only be granted to the proposed development as submitted if the following planning condition is imposed as set out below. Without this condition, the proposed development on this site poses an unacceptable risk to the environment and we would wish to object to the application.

Condition: Prior to the commencement of development approved by this planning permission (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved, in writing, by the local planning authority:

1. A preliminary risk assessment which has identified:
 - all previous uses
 - potential contaminants associated with those uses
 - a conceptual model of the site indicating sources, pathways and receptors
 - potentially unacceptable risks arising from contamination at the site.

2. A site investigation scheme, based on (1) to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
3. The site investigation results and the detailed risk assessment (2) and, based on these, an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
4. A verification plan providing details of the data that will be collected in order to demonstrate that the works set out in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Any changes to these components require the express consent of the local planning authority. The scheme shall be implemented as approved.

Reason

To ensure that the development complies with approved details in the interests of protection of the environment and prevention of harm to human health in accordance with policy DEV1 of the West Sussex Structure Plan and policies GEN7 and GEN31 of the Arun District Local Plan .

ENV 5 Unsuspected contamination

Environmental Health position

We consider that planning permission should only be granted to the proposed development as submitted if the following planning condition is imposed as set out below. Without this condition, the proposed development on this site poses an unacceptable risk to the environment and we would wish to object to the application.

Condition: If, during development, contamination not previously identified is found to be present at the site then no further development (unless otherwise agreed in writing with the Local Planning Authority) shall be carried out until the developer has submitted, and obtained written approval from the Local Planning Authority for, an amendment to the remediation strategy detailing how this unsuspected contamination shall be dealt with.

Reason

To ensure that the development complies with approved details in the interests of protection of the environment and prevention of harm to human health in accordance with policy DEV1 of the West Sussex Structure Plan and policies GEN7 and GEN31 of the Arun District Local Plan

ENV 6 Verification report

Environmental Health position

We consider that planning permission should only be granted to the proposed development as submitted if the following planning condition is imposed as set out below. Without this condition, the proposed development on this site poses an unacceptable risk to the environment and we would wish to object to the application.

Condition: Prior to [commencement of development]/ [occupation of any part of the permitted development], a verification report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of the remediation shall be submitted to and approved, in writing, by the local planning authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. It shall also include any plan (a “long-term monitoring and maintenance plan”) for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action, as identified in the verification plan, and for the reporting of this to the local planning authority.

REASON

To ensure that the development complies with approved details in the interests of protection of the environment and prevention of harm to human health in accordance with policy DEV1 of the West Sussex Structure Plan and policies GEN7 and GEN31 of the Arun District Local Plan.

From: Graham Evans
Sent: 15 September 2014 16:54
To: Matthew Kennett
Subject: FW: Planning Consultation on: WA/48/14/PL

Matt,

Previous industrial/commercial use. Please respond direct with any comments.

Thanks
Graham

From: Helen Mills
Sent: 05 September 2014 14:38
To: Pollution
Cc: Fiona Fitzgerald
Subject: FW: Planning Consultation on: WA/48/14/PL

205754

Helen

From: planning.responses@arun.gov.uk [mailto:planning.responses@arun.gov.uk]
Sent: 04 September 2014 10:34
To: EH Planning Consultations
Subject: Planning Consultation on: WA/48/14/PL

To: **Environmental Health - Graham Evans/Sarah Meeten**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2010 (as amended)

Planning Permission

APPLICATION WA/48/14/PL

NO:

Registered: 4th September
2014

Site Address: Deans Yard Orchard Way Fontwell BN18 0SJ

Grid Reference: 495480 107060

Description of Works: Demolition of existing commercial buildings/garages and erection of 3 No 2 bed terraced dwellings along with provision

of ancillary parking, turning and landscaping (re-submission of application WA/52/13).

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 09-OCT-14.

You can also monitor the progress of this application through the Council web site:
www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website:

www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Mr D Sullivan who can be contacted on telephone number 01903 737888.

Regards
Planning Officer

consultee_email
