

From: Laura Gibbons
Sent: 11 July 2019 15:59
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Raymond Cole <Raymond.Cole@arun.gov.uk>
Subject: RE: Planning Consultation on: WA/48/19/RES

Engineers Comments Regarding Surface Water Drainage

The surface water drainage proposals submitted require some re-evaluation to consider moving some soakaways so that sufficient easement between soakaways and buildings can be achieved. I would also request that soakaways are moved away from the red line boundary where possible.

There is a large degree of variation in infiltration rates across the site. Some soakaways are located in between previous infiltration testing locations where rates differed substantially. Assessing the adequacy of the surface water drainage design and layout is therefore difficult in these locations. Further infiltration testing is being completed to ascertain where the delineation in soil characteristics occurs.

A 10m offset is required between buildings and soakaways due to the presence of chalk in underlying strata. As a result, drainage and layout must be considered concurrently. I would therefore **request that further surface water drainage information is submitted prior to determination of this application to ensure that the development can adequately drain.**

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk <planning.responses@arun.gov.uk>
Sent: 13 June 2019 10:06
To: Land Drainage <Land.Drainage@arun.gov.uk>
Subject: Planning Consultation on: WA/48/19/RES

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

The Town & Country Planning Act 1990 (as amended)

Town & country Planning (Development Management Procedure) (England) Order 2015 - Article 6

Approval of Reserved Matters Following Outline Approval

APPLICATION NO: WA/48/19/RES

Registered: 28th May
2019

Site Address: Land to the East of Fontwell Avenue Fontwell Avenue Fontwell

Grid Reference: 495100 106820

Description of Works: Approval for Reserved Matters following outline permission WA/22/15/OUT comprising 400 new homes (incl. affordable), 360sqm of retail space (A1 to A3), 152sqm of community space (D1 to D2 & including retention & refurbishment of 12sqm 'old smithy'), demolition of remaining buildings to Arundel Road along with public open space, LEAP, MUGA, allotments, car & cycle parking, drainage & associated works - This site also lies within the parish of Eastergate

The Council have received the above application. I shall be pleased to receive any observations you may wish to make.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 18-JUL-19.

You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website as can the leaflet which deals with material planning considerations.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: www.planningportal.gov.uk/planning/appeals/ but they will protect personal details.

The officer dealing with this application is Raymond Cole who can be contacted on telephone number 01903 737598.

Regards
Planning Officer

