




From: Richard Atherton 
Sent: 25 September 2015 09:55
To: Anita Gardner
Subject: Swallowshaw materials

Hi Anita,

Following on from our telephone conversation this morning I am just confirming everything that is outstanding pending the decision,

Velux conservation roof lights.

After scaling the drawings I believe that using a 55w x 98h conservation Velux is the right size. The position of the Velux windows when standing in the new room are above 1.8mm therefore knowbody is unable to see through them on to neighbouring properties.

The neighbouring properties do have much larger Velux windows which are not conservation.

Roofing Slates.

I will drop a sample slate down to the offices today

Thermo wood cladding

I can confirm that this type of cladding has been heat treated and therefore the client will not be treating the thermo wood cladding with anything. It will be left in its natural form and left to silver off.

I look forward to hearing from you.

Kind Regards



Richard Atherton
Director

Atherton's Construction Ltd
Old Bank House, 1 - 3 High Street,
Arundel. BN18 9AD

