

**FROM: Adam Charlton TO: Arun District Council
FAO: Mr D Easton**

SUBJECT: WA/58/15/HH - Vehicular crossover within the Walberton Conservation Area.

Frogs Leap, 1, Walberton Green, Walberton, BN18 0AT

RECOMMENDATION:

Advice	☒	Modification	☐	More Information	☐
Objection	☐	No Objection	☐	Refusal	☐

This application has been dealt with in accordance with the Development Control Scheme protocol for small scale proposals which include up to 5 residential units or extensions to single units accessed from roads that do not form part of the Strategic Road Network (SRN). As such the comments provided by Strategic Planning should be considered to be advice only, with respect to this planning application.

This proposal has been considered by means of a desktop study, using the information and plans submitted with this application, in conjunction with other available WSCC map information. A site visit can be arranged on request.

The proposal is for a vehicular crossover with access onto The Street.

From an inspection of the plans alone, there is no apparent visibility issue at the point of access onto The Street. The applicants have entered into a dialogue with WSCC as the licencing authority for the crossover, to which advice was given as to an appropriate access point through the bus layby. It should also be noted that the crossover does not incur into land that has been designated as village green.

The most recently available verified accident records reveal there have been no personal injury accidents in the vicinity of the existing point of access, indicating a low risk of highway safety issues with this proposal.

There should not be a detriment to the safety of Highway users from this proposal.

CONDITION

No part of the development shall be first occupied until visibility splays of 2.4 metres by 43 metres have been provided at the proposed site vehicular access onto The Street in accordance with the approved planning drawings. Once provided the splays shall thereafter be maintained and kept free of all obstructions over a height of 0.6 metre above adjoining carriageway level or as otherwise agreed.

Reason: In the interests of road safety.

INFORMATIVE

The applicant is advised to contact the West Sussex Area Highways Officer covering the respective area (01243 642105) to obtain formal approval from the highway authority to carry out the site access works on the public highway.

**Adam Charlton
Strategic Planning**