



Exceedance banded area outlined PURPLE.

Attenuation tanks shown blue.

Drain runs shown dark green.

Orifice plate discharge is via the South Outfall - see separate drawing "Outfall south" for detail.

Attenuation capacity:-
2 x 512m3 = 1024m3

Largest tank = 512m3

Exceedance bund volume = 550m3

Fleurie Nursery
Lake Lane
Barnham

South Tunnel Exceedance

Date: 15.10.25
Scale 1:250 (A1)
Drawn AM

Revisions
30.1.26

Hennock International Ltd

Church Road
Hennock
Newton Abbot
Devon TQ13 9QE