

John Hall Consulting Ltd
113 Limmer Lane
Felpham
West Sussex
PO22 7LR

Please ask for: Mrs A Gardner
Email: Anita.Gardner@arun.gov.uk
Telephone: 01903 737529
Our Ref: WA/62/20/PL
Your Ref:
Date: 25th January 2021

Dear Mr Hall,

Town and Country Planning (Pre-commencement Conditions) 2018
Notice of intention to impose pre-commencement conditions

Construction Of 5 Hectares Of Glasshouses, A Service Area & A Reservoir On Agricultural Land. This Site Is In Cil Zone 3 (Zero Rated) As Other Development.

Lower Farm Yapton Lane Walberton BN18 0AS

From 1 October 2018 section 100ZA(5) of the Planning Act 1990 provides that planning permission for the development of land may not be granted subject to a pre-commencement condition without the written agreement of the applicant to the terms of the condition (except in the circumstances set out in the Town and Country Planning (Pre-commencement Conditions) Regulations 2018).

The following Pre Commencement Condition/s are Proposed:

- 3 Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

- 4 The development shall not proceed until details have been submitted to and approved in writing by the Local Planning Authority for any proposals: to discharge flows to watercourses; or for the culverting, diversion, infilling or obstruction of any watercourse on or adjacent to the site. Any discharge to a watercourse must be at a rate no greater than the pre-development run-off values. No construction is permitted, which will restrict current and future land owners from undertaking their riparian maintenance responsibilities in respect to any watercourse or culvert on or adjacent to the site.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W DM1, W DM2 and W DM3 of the Arun Local Plan. And to ensure that the duties and responsibilities, as required under the Land Drainage Act 1991, and amended by the Flood and Water Management Act 2010, can be fulfilled without additional impediment following the development completion. It is considered necessary for this to be a pre-commencement condition to protect existing watercourses prior to the construction commencing.

- 5 Development shall not commence until full details of the maintenance and management of the surface water drainage system is set out in a site-specific maintenance manual and submitted to, and approved in writing, by the Local Planning Authority. The manual is to include details of financial management and arrangements for the replacement of major components at the end of the manufacturer's recommended design life. Upon completed construction of the surface water drainage system, the owner or management company shall strictly adhere to and implement the recommendations contained within the manual.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W DM1, W DM2 and W DM3 of the Arun Local Plan. It is considered necessary for this to be a pre-commencement condition to ensure that the future maintenance and funding arrangements for the surface water disposal scheme are agreed before construction commences.

- 7 No development shall commence until a Construction Management Plan has been submitted to and approved in writing by the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters,

- the anticipated number, frequency and types of vehicles used during construction,
- the method of access and routing of vehicles during construction,
- the parking of vehicles by site operatives and visitors,
- the loading and unloading of plant, materials and waste,
- the storage of plant and materials used in construction of the development,
- the erection and maintenance of security hoarding,
- the provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulation Orders),
- details of public engagement both prior to and during construction works.

Reason: In the interests of highway safety and the amenities of the area in accordance with policy TSP1 of the Arun Local Plan.

14 Prior to the commencement of development the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved, in writing, by the Local Planning Authority:

1. A preliminary risk assessment which has identified:
all previous uses potential contaminants associated with those uses
a conceptual model of the site indicating sources, pathways and receptors potentially unacceptable risks arising from contamination at the site.
2. A site investigation scheme, based on (1) to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
3. The site investigation results and the detailed risk assessment (2) and, based on these, an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
4. A verification plan providing details of the data that will be collected in order to demonstrate that the works set out in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Any changes to these components require the express consent of the Local Planning Authority. The scheme shall be implemented as approved.

Where demolition is required 1. and 2. above should be submitted prior to demolition. Parts 3. and 4. can take place post demolition if necessary.

Reason: To ensure that the development complies with approved details in the interests of protection of the environment and prevention of harm to human health in accordance with Arun Local Plan policies QE SP1 and QE DM4. This is required to be a pre-commencement condition because these details have to be agreed and in place before any work commences.

15 Prior to commencement of any construction work (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), a verification report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of the remediation shall be submitted to and approved, in writing, by the Local Planning Authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. It shall also include any plan (a "long-term monitoring and maintenance plan") for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action, as identified in the verification plan, and for the reporting of this to the Local Planning Authority.

Reason: To protect the environment and prevent harm to human health by ensuring that the remediated site has been reclaimed in an appropriate standard in accordance with Arun Local Plan policies QE SP1 and QE DM4. This is required to be a pre-commencement condition because these details have to be agreed and in place before any work commences.

OPTIONS:

1. Confirm your acceptance in writing by the **8th February 2021**.
2. Choose not respond (i.e. remain silent). If there is no response by the **8th February 2021** the Local Planning Authority may grant planning permission subject to the terms of the pre-commencement condition specified in the notice.
3. Provide comments before the **8th February 2021** on the proposed pre-commencement condition, in which case that condition cannot be imposed.
4. Indicate before the **8th February 2021** that you do not agree to the terms of the proposed pre-commencement condition, in which case the Local Planning Authority may then either:
 - a. grant planning permission without the pre-commencement condition,
 - b. seek written agreement to an alternative pre-commencement condition, or
 - c. refuse to grant permission (if it considers that the disputed pre-commencement condition is necessary to make the development acceptable in planning terms).

If you wish to discuss the contents of this letter, or if there is anything you do not understand, please contact the case officer on the above extension.

Yours sincerely



Neil Crowther
Group Head of Planning

For details of how the Council will deal with your data please refer to our privacy notices on the website www.arun.gov.uk/planning-privacy-statements

If you have provided an email address, all correspondence including the decision notice will be sent by email. It is therefore important that you keep us informed if this changes during the course of this application.

To register to receive notification of planning applications in your area, please go to <https://www.arun.gov.uk/planning> and click into Local Planning Application Finder.