

2nd January 2013

Town & Country Planning Act 1990 (as amended)
Town & country Planning (Development Management Procedure) (England) Order 2010
(as amended)

Construction of two storey extension.
Sunny Corner Copse Lane Walberton

The following reply to a consultation has been received via Ocella's E Consultation Hub on 24th December 2012:

Engineer's comments:

* *

No details are given of the proposed method for disposing of surface water from the extension.

* *

*Details will be required for approval which must not be disposal to the foul sewer.
Standard Condition ENGD2A should be applied.*

* *

* *

Brian Holland | Engineering Services Manager, Engineering Services, Arun District Council

Location: 2nd Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37815 | External: +44 (0) 1903 737815 | E-mail: brian.holland@arun.gov.uk

The Arun and Chichester District Council coast protection and land drainage services are working in partnership

Visit our web sites at <a href="http://www.arun.gov.uk/"

title="blocked::blocked::http://www.arun.gov.uk/

blocked::http://www.arun.gov.uk/">www.arun.gov.uk and www.chichester.gov.uk

P Save the environment - think before you print.

* *

* *

* *

From: planningecons@arun.gov.uk [mailto:planningecons@arun.gov.uk]

Sent: 29 November 2012 17:01

To: Brian Holland

Subject: Planning Consultation on: WA/64/12/

* *