

From: David Herniman (Allan B Matthews) 
Sent: 05 October 2018 08:08
To: Nick Howard
Cc: Anita Gardner; 'BURRELL Peter'; 'MCKINLEY Niall'
Subject: Fontwell ref. WA/71 18/DOC


Dear Nick,

Another consideration here is that the previous building had both air conditioning and chiller condensers which had higher noise levels than the proposed units and these were situated on the same elevation ie. facing the eastern boundary without any attenuation, so it could be argued that the proposal is a improvement.

Regards,

David

David Herniman for
Allan B. Matthews R.I.B.A
Chartered Architect
37 Fore Street
Bovey Tracey
Devon TQ13 9AD



This e-mail, its attachments and any other items transmitted with it are confidential and intended only for the addressee named above. If you are not the intended recipient you must not use, copy or show to any other person the contents of this message. You should immediately reply to the sender and

delete the message from your computer system.

VIRUSES - Allan B. Matthews Chartered Architect cannot guarantee that this e-mail and attachments are free of viruses and you must ensure that you carry out your own virus checks Allan B. Matthews Chartered Architect accepts no liability for any loss or damage caused by software viruses.