




From: Nick Howard <Nick.Howard@arun.gov.uk>
Sent: 06 November 2020 12:53
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: RE: Planning Consultation on: WA/75/20/PL

Dear Sirs,

EH comments below for the above planning application with reference to the Arun District Council Environmental Health Planning Conditions;

I have checked on the maps and the entire site is highlighted as potentially contaminated. I would therefore recommend that if the proposed works involve breaking the ground surface, the full PCL condition (below) should be applied.

Planning Conditions

PCL02 – Full contaminated land

Prior to commencement of the development hereby approved (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved in writing by the Local Planning Authority:

1. A 'Preliminary Risk Assessment' which has identified: all previous (historical) uses; potential contaminants associated with those uses; a conceptual model of the site indicating sources, pathways and receptors; and potentially unacceptable risks arising from contamination at the site.
2. A 'Site Investigation Scheme', based on (1) above to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
3. Based on the 'Site Investigation Scheme' and the detailed risk assessment (2), an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
4. A 'Verification Report' providing details of the data that will be collected in order to demonstrate that the works set out in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Note: Any changes to these components, (1) to (4) require the express written consent of the Local Planning Authority.

The scheme shall be implemented as approved above and, prior to commencement of any construction work (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), a Verification Report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of that remediation shall be submitted to and approved in writing by the Local Planning Authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. The report shall also include a 'long-term monitoring and maintenance plan' for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action, as identified in the verification report, and for the reporting of this in writing to the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

CD01 – Construction/Demolition Management Plan

No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to, and approved in writing by, the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters:-

- a. An indicative programme for carrying out of the works;
- b. Details of the arrangements for public engagement / consultation both prior to and continued liaison during the construction works;
- c. Measures to minimise the noise (including vibration) generated by the construction process to include hours of work, proposed method of piling for foundations, the careful selection of plant and machinery and use of noise mitigation barrier(s);

- d. Details of any floodlighting, including location, height, type and direction of light sources and intensity of illumination;
- e. The parking of vehicles of site operatives and visitors;
- f. Loading and unloading of plant and materials, including permitted times for deliveries;
- g. Storage of plant and materials used in constructing the development;
- h. The erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate;
- i. The provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulations Orders);
- j. Measures to control the emission of dust and dirt during construction;
- k. A scheme for recycling / disposing of waste resulting from demolition and construction works i.e. no burning permitted.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

CD02 - Hours of working on construction/demolition sites

No construction / demolition activities shall take place, other than between 08:00 to 18:00 hours (Monday to Friday) and 08:00 to 13:00 hours (Saturday) with no 'noisy' work on Sunday or Bank Holidays

[In addition to these hours of working the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Notes: the words in square brackets may be adjusted to reflect site specific constraints

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Kind Regards

Nick Howard
Senior Environmental Health Officer
Environmental Health

T: 01903 737685

E: nick.howard@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex,
BN17 5LF

www.arun.gov.uk



Sign up to our newsletter [here](#)



From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 22 October 2020 15:21

To: EHPlanningConsultations [REDACTED]
Subject: Planning Consultation on: WA/75/20/PL

To: Environmental Health - Planning consultation

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town and Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission

Application No: WA/75/20/PL
Registered: 20th October 2020
Site Address: Fleurie Lake Lane (former Star Plants Nursery) Lake Lane Barnham PO20 0AL
Grid Reference: 497236 104593
Description of Works: New & replacement glasshouses & polytunnel structures. This application also lies within the parish of Yapton. This site is in CIL Zone 3 (Zero Rated) as other development.

The Council have received the above application.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by . You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning.

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website <https://www.arun.gov.uk/development-plan> as can the the leaflet how to respond to planning applications <https://www.arun.gov.uk/planning-application-comments> which deals with material planning considerations.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: <https://www.planningportal.co.uk/info/200207/appeals> but they will protect personal details.

In the absence of a reply within the period stated, I shall assume that you have no observations to make

Yours sincerely

Andrew Wood

Planning Officer- Arun District Council

Telephone: 01903 737768

Email: andrew.wood@arun.gov.uk

