

Z
F
S
T
S
A

[Redacted]

ation

Supplementary Plan pls. upload.

[Redacted]

[Redacted]

Dear Andrew,

Please find attached amend layout for plot six, It is included with the old layout of plot six so the changes can be seen.

regards

Peter

[Redacted]

Mr. Terry,

I have been awaiting further information from you regarding the following:

Phase 1 Ecology Report.

Elevation Plans – Dwelling 6.

Landscaping Plan.

Tree Protection Plan.



Highways - The applicant should clarify whether refuse collection will be from the roadside or within the site and demonstrate via swept path tracking that a fire appliance can enter and turn on site. The Fire appliance is required to reach within 45m of the furthest point of each building which does not currently appear to be the case.

Can you please submit the above information within 7 days of this email to avoid the application being refused on the grounds of insufficient information.

Do not hesitate to contact me on 01903 73768 should you wish to discuss the matter further.

Thank you,

Andrew Wood




Dear Andrew,

Many thanks, this will be with you shortly.

Please can you have them amend the online portal as this email sent in error is on the application.

Kind regards

Peter



Please ignore the email below. I have just been informed that this has been sent to me (and consequently you) in error.

Please provide the information as requested in my email dated Wednesday 23/10/2019 requiring the following Tree Protection Plan.

Unfortunately, the applicant has not provided a Tree Protection Plan showing the precise detail of what measures are to be applied and where. This is essential before we can recommend approval, as without a specific plan there is no way we can ensure retained trees will be protected.

Regards,

Mark

[Redacted]

[Redacted]

Mr. Terry,

Pls see attached further guidance on Tree Protection Plan required.

Thank you,

Andrew Wood

[Redacted]

[Redacted]

Hi Andrew

Perhaps I should have clarified my concern with the Tree Protection Plans.

The plan is neither to scale nor based on a topographical map – so it is not possible to determine precisely where the tree protection measures are to be installed. It is only a sketched drawing (an illustration at best) – which is surprising given the typical standard of plans submitted (this was a first for me!) and not at all consistent with the high standard of report it is associated with.

Once we have a detailed and accurate plan, I can then quickly prepare a couple of bespoke conditions for you.

Hope that makes more sense.

Regards,

Mark

[Redacted]


Andrew

I have read through the attached Tree Survey Report. In general, it makes an adequate appraisal of the site (trees) and describes methodology for protection measures.

Unfortunately, the applicant has not provided a Tree Protection Plan showing the precise detail of what measures are to be applied and where. This is essential before we can recommend approval, as without a specific plan there is no way we can ensure retained trees will be protected.

Regards,


Mark



Comments please.

Thank you,

Andrew Wood




Dear Andrew,

Please find attached Tree report please let me know if you require any additional information

kind regards

Peter



Can you give me a call regarding this on 01903 737768.

Thank you,

Andrew Wood

[REDACTED]

[REDACTED]

Andrew,

I really fail to see how this can be the case when white cottage next door will have dormers and Richmond house has velux windows in the roof, like I said it doesn't change the height of the dwellings and if like I propose moving the dormers to the back/rear elevation they would not be visible from any point outside the site and only from the properties own back gardens, This should then have no conflict with policy D DM1 as it would be in character from all vantage points to the properties from Arundel road and west walberton lane.

I would understand the objection if we weren't willing to move the dormers so they were visible. It would seem stupid to have these loft spaces sitting empty when they have to be built anyway and would I believe certainly conflict with NPPF to ensure good use of space.

Kind regards

Peter

[REDACTED]

Peter,

the issue with the rooms in the roof is that the appearance of the dwellings will be of a town house which is simply not appropriate in this location. I would strongly advise you to remove this element from the scheme. To avoid the risk of the development being viewed as 'out of character' in the area and contrary to policy D DM1 of the Arun Local Plan. I have discussed the matter with my line management team and everyone is of the same view in this case.

I look forward to receiving the further information as promised.

Thank you,

Andrew Wood

[REDACTED]



Good morning,

Thank you for your email, apologies for the delay it went in the spam folder.

1, Happy to amend property six to make a nine metre distance.


2, we fail to see the merit in removing the room in the roof, this would have no impact on the height of the buildings and would result in empty lift spaces which would not allow for good use of space as per the NPPF. You will note from drawing 19-001-PL-03 all the dormers on houses 3-6 are in the south and therefore can not be seen from the front or any point outside the properties. Currently prosperities one and two have the dormers on the north but I would be happy to move these to the south so these are the same and none can be seen from Arundel road. I also would like to mention the design of white cottage next door that will have dormers in the roof and Richmond house which has velum windows in the roof. As previously mentioned the new ridge heights will be lower than the current house at Lanes end this can be seen in the scale drawings provided. If you could let me know if this is acceptable as if possible to avoid I would prefer not to have to appeal the reserved matters for this small item.

I am currently having the surveys and drawings you have asked for drawn up and hope to have these to you shortly, I also mention that the buildings will not be visible from west walberton lane as the current line of trees along the lane are to be kept to keep the lane 'looking like a country lane' which was one of the councillors request when the outline permission was granted at committee.

All TPO trees are to be protected and remain along with other mature trees and the survey will confirm this with the required protection measures (fencing off/signage, pile foundations where required)

Many thanks

Peter



Mr. Terry,

WA/7/19/RES - Lanes End, West Walberton Lane - Additional information request

In order to avoid refusal of the application on grounds of loss of amenity and proposed development being out of character with surrounding area can you;

1. Amend the layout to ensure that a minimum of 9 metres exists on from blank gable end (or obscure glazed windows non opening below 1.7 metres in height) of nearest proposed house to gable end of 'Woodlands' which currently incorporates sole habitable room windows.
2. Remove second storey of houses/rooms in roof. 3 storey townhouses would not be acceptable in this location

The following information is required to assess this application:

1. Ecology – Extended Phase One Habitat Survey.
2. Trees – Arboricultural Impact Assessment & Method Statement along with a Tree Retention Protection Plan.

3. Highways - Floor plans (houses and garages) providing clarification of refuse collection and demonstration via swept path tracking that refuse and fire appliance can turn within the site, ideally reaching within 45m of furthest point of each building.
4. Scale drawing showing the comparative heights of the buildings and neighbouring buildings from West Walberton Lane.

Do not hesitate to contact me should you require any clarification of this email.

Thank you,

Andrew Wood

<http://www.arun.gov.uk>
DX 57406 Littlehampton
You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>
DX 57406 Littlehampton
You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>
DX 57406 Littlehampton
You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<http://www.arun.gov.uk>
DX 57406 Littlehampton
You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.

<https://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
