



Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: southernwaterplanning@atkinsglobal.com

Your Ref

WA/88/17/PL

Our Ref

PLAN-022439

Date

17/04/2018

Dear Sirs,

Proposal: External alterations including replacement windows & doors to create new entrance, cladding of external walls & creation of seating area to facilitate new operator (KFC) together with provision of drive-thru lane (use class A3/A5) with opening hours 7am to 10pm and single storey extension to Burger King to South.

Site: Little Chef Restaurant, Arundel Road, Walberton, BN18 0SB.
WA/88/17/PL

Thank you for your letter of 06/03/2018.

Southern Water requires a formal application for a connection to the public sewer to be made by the applicant or developer.

We request that should this application receive planning approval, the following informative is attached to the consent:

A formal application for connection to the public sewerage system is required in order to service this development, please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk. Please read our New Connections Services Charging Arrangements documents which has now been published and is available to read on our website via the following link <https://beta.southernwater.co.uk/infrastructure-charges>.

It is the responsibility of the developer to make suitable provision for the disposal of surface water. Part H3 of the Building Regulations prioritises the means of surface water disposal in the order

- a Adequate soakaway or infiltration system
- b Water course
- c Where neither of the above is practicable sewer

Southern Water supports this stance and seeks through appropriate Planning Conditions to ensure that appropriate means of surface water disposal are proposed for each development. It is important that discharge to sewer occurs only where this is necessary and where adequate capacity exists to serve the development. When it is proposed to connect to a public sewer the prior approval of Southern Water is required.

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development.

Due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site.

The applicant is advised to discuss the matter further with Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119) or www.southernwater.co.uk.

Yours sincerely,

A black rectangular box redacting the signature of the person representing Developer Services.

Developer Services

The map illustrates the Fontwell area, showing a proposed railway line (dashed line) and various landmarks. The map includes labels for 'A 27', 'A 29', 'Motel', 'Fontwell Services', 'Park Cottage', 'Tamarisk', 'Gwenner', 'Old Police houses', 'FW', 'Too Coppers', 'El Sub Sta', 'Services', 'Def', and 'Tamarisk'. It also features several numbered points (0001, 0002, 0003, 0004, 0005) and distances (0.91m, 31.4m). The map is overlaid with a grid of dotted lines.



Requested By: