

From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 21 January 2022 10:54
To: David Easton <David.Easton@arun.gov.uk>
Subject: RE: WA/88/21/DOC

Hi David,

Having assessed the revised CMP, EH is happy for Condition 19 (CMP) to be discharged.

Fiona

Fiona Fitzgerald
Senior Environmental Health Officer
Environmental Health

T: 01903 737674
E: fiona.fitzgerald@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)



From: David Easton <David.Easton@arun.gov.uk>
Sent: 18 January 2022 10:11
To: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Subject: RE: WA/88/21/DOC

Hi Fiona,

Following your initial comments we have received a revised CMP. Are you able to review and let me know if this has addressed your comments.

Many thanks,
David

From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 14 December 2021 12:00
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: David Easton <David.Easton@arun.gov.uk>
Subject: WA/88/21/DOC

Dear Planning,

With respect to Condition 21, providing that the mitigation measures and controls referred to in Section 3.4 are complied with, Environmental Health is satisfied and does not have any further comments.

Condition 19 – CMP:

1. Paragraph 6 – there are other potential noise sensitive residences close to the site other than the dwelling to the north east. Please could these other premises be identified, and potential impacts from the works be assessed?
2. Please could the hours of work in paragraph 9 be amended to 8am – 6pm Monday to Friday, 8am – 1pm Saturdays and no work on Sundays and Public Holidays.
3. Paragraph 13 – please could specific details of wheel washing facilities be provided?
4. Paragraph 15 – insufficient information. Please could further detailed information be provided?
5. Paragraph 16 – please could specific information be provided on mitigation measures to be incorporated during the construction works to prevent noise and vibration disturbances?
6. Paragraph 19 – insufficient information. Please could specific details be given on the arrangements of monitoring for noise, vibration and dust levels?

Environmental Health is therefore satisfied that condition 21 may be discharged, but states that **there is insufficient information for Condition 19 to be discharged.**

Regards

Fiona Fitzgerald
Senior Environmental Health Officer
Environmental Health

T: 01903 737674
E: fiona.fitzgerald@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk



Sign up to our newsletter [here](#)