

[REDACTED]

From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 01 June 2021 12:55
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Michael Eastham <Michael.Eastham@arun.gov.uk>
Subject: RE: Planning Consultation on: WA/93/20/PL

Further Surface Water Drainage/ Land Drainage Comments

We maintain our holding objection at this time. No further specific details on the proposals for the revised watercourse crossing or the roadside ditch have been provided. It appears from the arboricultural statement and drawings that the ditch is to be infilled, yet no specific information on this as per our previous consultation has been supplied.

As per WSCC policy culverting and infilling of watercourses is not supported.

Please can the applicant submit a statement and details specific to the proposals for the watercourse.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk or [REDACTED]

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

From: Planning.Responses <Planning.Responses@arun.gov.uk>
Sent: 05 April 2021 12:19
To: Land Drainage <Land.Drainage@arun.gov.uk>
Subject: Planning Consultation on: WA/93/20/PL

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: WA/93/20/PL
Registered: 30th March 2021
Site Address: Land East of Tye Lane Walberton BN18 0LU
Grid Reference: 497404 106234
Category: Plan Applicat'n
Description of Works: Alternative vehicular access off Tye Lane & emergency access off Avisford Park Road, along with minor highway works following WA/95/18/RES. This site is in CIL Zone 2 (Zero Rated) as other development.

I am able to inform you that I have received an amendment to the above application dated 5th April 2021 relating to:- amended Location plan and additional plans

[Click here to view the plans and documents](#)

If you should wish to make further representations as a result of this amendment you should click the link below and then click on 'Enter comment'.

[Click here to make further comments](#)

Please make any further comment by **14th May 2021**.

Please be aware that Planning Services operate an 'open file' policy and will publish your comments including your name and address on the website. We will aim to redact signatures, telephone numbers and email addresses but please help us by not incorporating them in the body of your text. Please make sure that you only include information that you are happy will be published in this way. If you supply information belonging to a third party, you must make sure you have their permission to do so.

Yours sincerely

Michael Eastham

Planning Case Officer- Arun District Council

Telephone: 01903 737772

Email: michael.eastham@arun.gov.uk

PLRECON (CDB) 2018