

Arun District Council
Development Control
1, Arun Civic Centre Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Our ref: HA/2021/122860/02-L01
Your ref: WA/99/20/DOC
Date: 13 April 2021

Dear Sir/Madam

ADDITIONAL DOCS - APPROVAL OF DETAILS RESERVED BY CONDITION IMPOSED UNDER REF APP/C3810/V/16/3143095 (WA/22/15/OUT) RELATING TO CONDITION NOS 6 - MATERIALS AND FINISHES, 12 - SURFACE WATER DRAINAGE, 13 - INFILTRATION OF SURFACE WATER DRAINAGE, 14 - MAINTENANCE & MANAGEMENT OF SUDS, 15 - FOUL DRAINAGE AND 27 - EMERGENCY ACCESS FROM SITE ONTO ARUNDEL ROAD.

LAND TO THE EAST OF FONTWELL AVENUE FONTWELL

Thank you for consulting the Environment Agency on the above application.

Environment Agency Position

We have reviewed the information submitted and **recommend the discharge of condition 13**. Letter reference LD/WSC/E4736/17822 states that the maximum depth of the soakaways is 4.5m and that they do not penetrate the chalk principal aquifer. We are satisfied that this mitigates against the risks to the underlying chalk aquifer.

Should you have any further queries please do not hesitate to contact me.

Yours faithfully

Miss Hannah Brothwell
Sustainable Places Advisor

cc Dandra

Environment Agency
Environment Agency Depot Canal Walk, Romsey, Hampshire, SO51 7LP.
Customer services line: [REDACTED]
www.gov.uk/environment-agency

End