

Our Ref: PEF/SD/28854
Your Ref: Y/21/18/DOC

30 April 2018

By E-Mail:

Laura Gibb
Engineering Services
Arun District Council
Arun Civic Centre
Mailtravers Road
Littlehampton
West Sussex
BN17 5LF

Dear Laura

**Drainage
Land at Kings Close, Yapton**

Further to receipt of your e-mail dated 30 April 2018, please find attached the following drawings:-

- 28854-101.P4 – General Arrangement
- STD-01-47 A – Catchpit Chambers
- Flow exceedance flow route mark up
- 28854-106.P2 – King Post retaining wall
- 28854-107.P1 – King Post retaining wall

I respond to the items that you raise as follows:-

- Soakaway base and cover levels have been added to our drawing No. 28854-101.P4. Base levels represent the invert level of the storage void former.
- Step rungs have been added to our drawing No. STD.01.47A. Manholes Type P2 have not had step rungs detailed to accord with adopted manhole details.
- The depth of the concrete bed at the base of the catchpits has been increased to 225mm.
- Manhole cover types and grades are shown on the schedules and standard drawings. Cover grades A15, B125, C250 and D400 imply compliance with BS EN124.
- Our marked-up drawing shows flood exceedance flow routes.
- Drawings 106.P2 and 107.P1 show sections through the proposed king post retaining wall.

I trust that the surface Water Planning Condition for the project can now be consented.

Yours sincerely,

Philip Faulkner EngTech MICE
for ARCHIBALD SHAW

Enc

cc: Raymond
Michael G
Vince Carp

John Lord, BEng (Hons)
Eur Ing Vincent Carpenter, BSc (Hons) BEng MICE FCIEM IMHT MSc
Ian Sheppard, BEng (Hons) CEng MInstE

Neil Graham, CEng MInstE
Neil Stanaway, BEng (Hons) CEng MInstE

Peter Willmott, CEng MInstE
Jonathan Pains, BSc (Eng) MICE
Lawrence Jupp, BSc (Hons) CEng MInstE

Archibald Shaw LLP uses the word 'Partner' to refer to a Member of the LLP

Also at Newbury