

From: Amanda Scholes on behalf of Planning.Responses
Sent: 27 November 2019 08:57
To: Planning Scanning
Subject: FW: Y/101/19/DOC - Yapton View (land off Burndell Road), Yapton, BN18 0HW

From: Kate Giddings <kate.giddings@arun.gov.uk>
Sent: 26 November 2019 16:13
To: Simon Davis <Simon.Davis@arun.gov.uk>
Cc: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: Y/101/19/DOC - Yapton View (land off Burndell Road), Yapton, BN18 0HW

Dear Simon,

In relation to the above application, I understand from the submitted documents that Geo-Environmental's Remediation Strategy and Verification Report (ref.: GE18533/RSVR/SEP19, dated September 2019) has been provided with the aim of allowing discharge of condition 3 (remediation strategy) and condition 5 (verification plan). In order for this Department to consider discharging the conditions, please may the following points be addressed:

- date(s) of remedial work (it is noted that the visit to confirm the mass excavation was 15 April 2019)
- provision of the post-excavation validation sampling
- evidence of removal of material from site to a suitable facility (hazardous waste)
- evidence of the membrane placement
- evidence of material imported to site

Furthermore, the applicant/developer must confirm how the Japanese knotweed on site will be managed.

Many thanks,

Kate.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF
Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.