

Arun District Council
Development Control
1, Arun Civic Centre Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Our ref: HA/2019/121021/01-L01
Your ref: Y/103/18/PL
Date: 23 January 2019

Dear Sir/Madam

SINGLE CHAPEL CREMATORIUM WITH CAR PARKING, LANDSCAPE WORKS, SURFACE WATER DRAINAGE FEATURES & ASSOCIATED HIGHWAY IMPROVEMENTS. THIS APPLICATION IS A DEPARTURE FROM THE DEVELOPMENT PLAN.

10 ACRE FIELD NORTH OF GREVATTS LANE YAPTON

Thank you for the consultation on the above application, please quote our reference on all correspondence.

This development is sited on River Terrace Deposits overlying the Lewes Nodular Chalk which is designated a principal aquifer. There are a number of surface water features within close proximity of the site, therefore controlled waters need to be protected from contamination.

Environment Agency Position

We have no objection to this development but would like to offer the following advice to the applicant regarding the need for an environmental permit for the discharge of effluent from this site.

Advice to applicant

The discharge of effluent associated with this development will require an Environmental Permit under the Environmental Permitting (England & Wales) Regulations 2016, from the Environment Agency, unless an exemption applies. The applicant is advised to contact the Environment Agency on 03708 506 506 for further advice and to discuss the issues likely to be raised. You should be aware that there is no guarantee that a permit will be granted. Additional 'Environmental Permitting Guidance' can be found at: <https://www.gov.uk/environmental-permit-check-if-you-need->


Environment Agency
Canal Walk, ROMSEY, Hampshire, SO51 7LP.
Customer services line: 03708 506 506
www.gov.uk/environmental-agency

Cont/d..

one.

Yours faithfully

Miss Suz Greenwood
Planning Advisor, Environment Agency



End

2