

[REDACTED]

From: Sarah Burrow <Sarah.Burrow@arun.gov.uk>

Sent: 29 April 2020 08:59

To: Paul Rhodes [REDACTED]
[REDACTED]

Subject: RE: Hazel Cottage

Hi Paul,

Thank you for your very prompt reply. I can confirm that although the calculations appear to be incomplete, the design meets the requirements to store the surface water for a 1 in 100 year +40% storm event. I would have normally expected a separate detail for the silt trap/pipe bed and surround, however, the design is very clear on the drawings and I believe that a contractor could easily follow them to be able to construct the drainage design in accordance with what has been agreed (which is the point of the exercise). As such, **I am happy for Amber to discharge the condition on the planning application.**

Amber please let me know if you need any more information from me.

I wish you good luck on your build.

Kind Regards

Sarah Burrow
Engineering Assistant

From: Paul Rhodes [REDACTED]

Sent: 28 April 2020 13:57

To: Sarah Burrow <Sarah.Burrow@arun.gov.uk>



