Summary of Results for 100 year Return Period (+40%)

Half Drain Time : 2198 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
15 min Summer	0.079	0.079	0.0	0.8	O K
30 min Summer	0.106	0.106	0.0	1.1	Flood Risk
60 min Summer	0.135	0.135	0.0	1.3	Flood Risk
120 min Summer	0.158	0.158	0.0	1.6	Flood Risk
180 min Summer	0.172	0.172	0.0	1.7	Flood Risk
240 min Summer	0.181	0.181	0.0	1.8	Flood Risk
360 min Summer	0.192	0.192	0.0	1.9	Flood Risk
480 min Summer	0.198	0.198	0.0	2.0	Flood Risk
600 min Summer	0.201	0.201	0.0	2.0	Flood Risk
720 min Summer	0.204	0.204	0.0	2.0	Flood Risk
960 min Summer	0.205	0.205	0.0	2.0	Flood Risk
1440 min Summer	0.203	0.203	0.0	2.0	Flood Risk
2160 min Summer	0.197	0.197	0.0	2.0	Flood Risk
2880 min Summer	0.192	0.192	0.0	1.9	Flood Risk
4320 min Summer	0.185	0.185	0.0	1.8	Flood Risk
5760 min Summer	0.179	0.179	0.0	1.8	Flood Risk
7200 min Summer	0.174	0.174	0.0	1.7	Flood Risk
8640 min Summer	0.171	0.171	0.0	1.7	Flood Risk
10080 min Summer	0.168	0.168	0.0	1.7	Flood Risk
15 min Winter	0.089	0.089	0.0	0.9	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
15 min Summer	141.164	0.0	19
30 min Summer	94.700	0.0	34
60 min Summer	60.903	0.0	64
120 min Summer	36.128	0.0	124
180 min Summer	26.473	0.0	184
240 min Summer	21.126	0.0	244
360 min Summer	15.214	0.0	362
480 min Summer	12.016	0.0	482
600 min Summer	9.993	0.0	602
720 min Summer	8.590	0.0	722
960 min Summer	6.756	0.0	962
1440 min Summer	4.823	0.0	1440
2160 min Summer	3.462	0.0	1820
2880 min Summer	2.754	0.0	2188
4320 min Summer	2.025	0.0	2980
5760 min Summer	1.648	0.0	3808
7200 min Summer	1.419	0.0	4616
8640 min Summer	1.264	0.0	5448
10080 min Summer	1.153	0.0	6264
15 min Winter	141.164	0.0	19

©1982-2020 Innovyze

Summary of Results for 100 year Return Period (+40%)

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
30 min Winter	0.118	0.118	0.0	1.2	Flood Risk
60 min Winter	0.151	0.151	0.0	1.5	Flood Risk
120 min Winter	0.178	0.178	0.0	1.8	Flood Risk
180 min Winter	0.193	0.193	0.0	1.9	Flood Risk
240 min Winter	0.204	0.204	0.0	2.0	Flood Risk
360 min Winter	0.216	0.216	0.0	2.2	Flood Risk
480 min Winter	0.223	0.223	0.0	2.2	Flood Risk
600 min Winter	0.228	0.228	0.0	2.3	Flood Risk
720 min Winter	0.231	0.231	0.0	2.3	Flood Risk
960 min Winter	0.234	0.234	0.0	2.3	Flood Risk
1440 min Winter	0.234	0.234	0.0	2.3	Flood Risk
2160 min Winter	0.228	0.228	0.0	2.3	Flood Risk
2880 min Winter	0.220	0.220	0.0	2.2	Flood Risk
4320 min Winter	0.210	0.210	0.0	2.1	Flood Risk
5760 min Winter	0.200	0.200	0.0	2.0	Flood Risk
7200 min Winter	0.191	0.191	0.0	1.9	Flood Risk
8640 min Winter	0.184	0.184	0.0	1.8	Flood Risk
10080 min Winter	0.177	0.177	0.0	1.8	Flood Risk

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
30 min Winter	94.700	0.0	34
60 min Winter	60.903	0.0	64
120 min Winter	36.128	0.0	122
180 min Winter	26.473	0.0	182
240 min Winter	21.126	0.0	240
360 min Winter	15.214	0.0	358
480 min Winter	12.016	0.0	476
600 min Winter	9.993	0.0	594
720 min Winter	8.590	0.0	708
960 min Winter	6.756	0.0	942
1440 min Winter	4.823	0.0	1396
2160 min Winter	3.462	0.0	2036
2880 min Winter	2.754	0.0	2336
4320 min Winter	2.025	0.0	3240
5760 min Winter	1.648	0.0	4152
7200 min Winter	1.419	0.0	5048
8640 min Winter	1.264	0.0	5960
10080 min Winter	1.153	0.0	6848

©1982-2020 Innovyze

Rainfall Details

Rainfall Model	FEH
Return Period (years)	100
FEH Rainfall Version	2013
Site Location	GB 497682 103581 SU 97682 03581
Data Type	Point
Summer Storms	Yes
Winter Storms	Yes
Cv (Summer)	0.750
Cv (Winter)	0.840
Shortest Storm (mins)	15
Longest Storm (mins)	10080
Climate Change %	+40

Time Area Diagram

Total Area (ha) 0.003

Time (mins) From:	To:	Area (ha)
0	4	0.003

©1982-2020 Innovyze

Model Details

Storage is Online Cover Level (m) 0.400

Infiltration Blanket Structure

Infiltration Coefficient Base (m/hr)	0.00612	Diameter/Width (m)	3.0
Safety Factor	2.0	Length (m)	3.5
Porosity	0.95	Cap Volume Depth (m)	0.000
Invert Level (m)	0.000		

©1982-2020 Innovyze