Summary of Results for 100 year Return Period (+40%)

Half Drain Time : 1771 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
15 min Summer	0.058	0.058	0.0	1.6	O K
30 min Summer	0.077	0.077	0.0	2.1	O K
60 min Summer	0.099	0.099	0.0	2.7	O K
120 min Summer	0.116	0.116	0.0	3.1	Flood Risk
180 min Summer	0.126	0.126	0.0	3.4	Flood Risk
240 min Summer	0.132	0.132	0.0	3.6	Flood Risk
360 min Summer	0.139	0.139	0.0	3.8	Flood Risk
480 min Summer	0.143	0.143	0.0	3.9	Flood Risk
600 min Summer	0.146	0.146	0.0	4.0	Flood Risk
720 min Summer	0.147	0.147	0.0	4.0	Flood Risk
960 min Summer	0.147	0.147	0.0	4.0	Flood Risk
1440 min Summer	0.144	0.144	0.0	3.9	Flood Risk
2160 min Summer	0.139	0.139	0.0	3.8	Flood Risk
2880 min Summer	0.136	0.136	0.0	3.7	Flood Risk
4320 min Summer	0.129	0.129	0.0	3.5	Flood Risk
5760 min Summer	0.124	0.124	0.0	3.4	Flood Risk
7200 min Summer	0.120	0.120	0.0	3.3	Flood Risk
8640 min Summer	0.116	0.116	0.0	3.2	Flood Risk
10080 min Summer	0.113	0.113	0.0	3.1	Flood Risk
15 min Winter	0.065	0.065	0.0	1.8	O K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
15 min Summer	141.164	0.0	19
30 min Summer	94.700	0.0	34
60 min Summer	60.903	0.0	64
120 min Summer	36.128	0.0	124
180 min Summer	26.473	0.0	184
240 min Summer	21.126	0.0	242
360 min Summer	15.214	0.0	362
480 min Summer	12.016	0.0	482
600 min Summer	9.993	0.0	602
720 min Summer	8.590	0.0	722
960 min Summer	6.756	0.0	960
1440 min Summer	4.823	0.0	1340
2160 min Summer	3.462	0.0	1668
2880 min Summer	2.754	0.0	2048
4320 min Summer	2.025	0.0	2856
5760 min Summer	1.648	0.0	3688
7200 min Summer	1.419	0.0	4536
8640 min Summer	1.264	0.0	5352
10080 min Summer	1.153	0.0	6144
15 min Winter	141.164	0.0	19

©1982-2020 Innovyze

Summary of Results for 100 year Return Period (+40%)

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Volume (m³)	Status
30 min Winter	0.087	0.087	0.0	2.4	O K
60 min Winter	0.111	0.111	0.0	3.0	Flood Risk
120 min Winter	0.130	0.130	0.0	3.5	Flood Risk
180 min Winter	0.141	0.141	0.0	3.8	Flood Risk
240 min Winter	0.149	0.149	0.0	4.0	Flood Risk
360 min Winter	0.157	0.157	0.0	4.3	Flood Risk
480 min Winter	0.162	0.162	0.0	4.4	Flood Risk
600 min Winter	0.165	0.165	0.0	4.5	Flood Risk
720 min Winter	0.167	0.167	0.0	4.5	Flood Risk
960 min Winter	0.168	0.168	0.0	4.6	Flood Risk
1440 min Winter	0.166	0.166	0.0	4.5	Flood Risk
2160 min Winter	0.159	0.159	0.0	4.3	Flood Risk
2880 min Winter	0.154	0.154	0.0	4.2	Flood Risk
4320 min Winter	0.144	0.144	0.0	3.9	Flood Risk
5760 min Winter	0.135	0.135	0.0	3.7	Flood Risk
7200 min Winter	0.127	0.127	0.0	3.4	Flood Risk
8640 min Winter	0.120	0.120	0.0	3.3	Flood Risk
10080 min Winter	0.113	0.113	0.0	3.1	Flood Risk

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Time-Peak (mins)
30 min Winter	94.700	0.0	34
60 min Winter	60.903	0.0	64
120 min Winter	36.128	0.0	122
180 min Winter	26.473	0.0	180
240 min Winter	21.126	0.0	240
360 min Winter	15.214	0.0	358
480 min Winter	12.016	0.0	474
600 min Winter	9.993	0.0	590
720 min Winter	8.590	0.0	708
960 min Winter	6.756	0.0	934
1440 min Winter	4.823	0.0	1382
2160 min Winter	3.462	0.0	1944
2880 min Winter	2.754	0.0	2220
4320 min Winter	2.025	0.0	3116
5760 min Winter	1.648	0.0	4032
7200 min Winter	1.419	0.0	4896
8640 min Winter	1.264	0.0	5712
10080 min Winter	1.153	0.0	6560

©1982-2020 Innovyze

Rainfall Details

Rainfall Model	FEH
Return Period (years)	100
FEH Rainfall Version	2013
Site Location	GB 497682 103581 SU 97682 03581
Data Type	Point
Summer Storms	Yes
Winter Storms	Yes
Cv (Summer)	0.750
Cv (Winter)	0.840
Shortest Storm (mins)	15
Longest Storm (mins)	10080
Climate Change %	+40

Time Area Diagram

Total Area (ha) 0.006

Time (mins) From:	To:	Area (ha)
0	4	0.006

©1982-2020 Innovyze

Model Details

Storage is Online Cover Level (m) 0.400

Infiltration Blanket Structure

Infiltration Coefficient Base (m/hr)	0.00540	Diameter/Width (m)	5.5
Safety Factor	2.0	Length (m)	5.2
Porosity	0.95	Cap Volume Depth (m)	0.000
Invert Level (m)	0.000		

©1982-2020 Innovyze