



from
**Southern
Water**

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Your ref
Y/113/20/DOC

Our ref
PLAN-036425

Date
10/12/2020

Dear Sir/Madam,

Proposal: Approval of details reserved by condition imposed under Y/80/16/OUT (APP/C3810/W/17/3170059) relating to conditions 11-sustainable drainage & 15-foul water sewerage.

Site: Y/113/20/DOC: - Land South of Ford Lane/ East of North End Road, Yapton, BN18 0DS.


Thank you for your letter dated 04/12/2020.

Southern Water would have no objections to condition 15 relating to foul sewerage drainage. No discharge of foul sewerage from the site shall be discharged into the public system until offsite drainage works to provide sufficient capacity within foul network to cope with additional sewerage flows are complete. Southern Water is currently in process of designing and planning delivery of offsite sewerage network reinforcements. As previously advised Southern Water seeks to limit the timescales to a maximum of 24 months from a firm commitment of the development.

The Council's Building Control officers/technical staff and the Environment Agency should be consulted regarding the surface water disposal to pond/ditch.

For any queries please contact us at: 

Yours faithfully,


Joff Edevane
Growth Planning Lead
Business Channels

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SU9803NW

Scale: 1:2500

Screen Print

WARNING: BAC pipes are constructed of Bonded Asbestos Cement

WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement

ARUN DISTRICT COUNCIL Y/113/20/DOC



Printed By: sheetyv

Date: 9-12-2020

Southern Water MapGuide Browser

Requested By: