

From: Kate Giddings <kate.giddings@arun.gov.uk>
Sent: 20 January 2020 15:35
To: James Cross <James.Cross@arun.gov.uk>
Cc: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: RE: Y/114/19/DOC - Cinders Lane Nursey and Works to the Rear

Dear James,

Thank you for providing the responses to my queries; I can confirm that these are satisfactory. EH cannot recommend discharge of the entire condition as half of point 3 and point 4 remain outstanding, however I understand that a partial discharge programme has been agreed. Once the remediation strategy has been submitted and agreed, part 3 of condition 10 can therefore be considered fulfilled. Part 4 relates to a verification plan which should be provided post-remediation and will be separately considered.

Planning Responses – please note that the 17962 Summary spreadsheet is not a public document and should therefore not be uploaded to the portal.

Many thanks,

Kate.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF

Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 20 January 2020 12:01
To: Kate Giddings <kate.giddings@arun.gov.uk>
Subject: FW: RE: Y/114/19/DOC - Cinders Lane Nursey and Works to the Rear



From: James Cross <James.Cross@arun.gov.uk>

Sent: 20 January 2020 09:23

To: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: FW: RE: Y/114/19/DOC - Cinders Lane Nursesey and Works to the Rear

Hi Fiona,

Planning Responses – could the attached documents be uploaded to the application file and labelled as ‘Discharge of Condition Additional Supporting Information’ please?

As requested by the applicants, please see updated information. I’d ideally like to get the DOC application finalised by Thursday of this week. Therefore, if you are able to provide feedback/confirmation throughout the former part of this week I would be most grateful?

Kindest regards,

James Cross Bsc (Hons) MSc Lcgi TP. MRTPI

Senior Planning Officer

Arun District Council, Maltravers Road, Littlehampton, BN17 5LF

Email: james.cross@arun.gov.uk | DD: 01903 737784

From: Emma Jones [REDACTED]

Sent: 17 January 2020 16:18

To: James Cross <James.Cross@arun.gov.uk>

Subject: RE: RE: Y/114/19/DOC - Cinders Lane Nursesey and Works to the Rear

Hi James,

Please find attached amended report and corresponding data in response to the comments from the environmental health officer.

Please see e-mail below for direct responses in red.

If you have any more queries please let me know.

Is it possible to discharge any of the other submitted conditions in the meantime please?

Thank you &

Kind regards

Emma

Emma Jones

Architect BA(Hons) MArch

Crayfern Homes Ltd 14 St John's Rd, Hedge End, Southampton SO30 4AB

www.crayfernhomes.co.uk



Follow our Facebook



Private Ltd Company registered in England and Wales. Registered Company: 02703219. Registered Company Address: Apollo House, Mercury Park, Wooburn Green, HP10 0HH IMPORTANT: This message is intended for the addressee only and may contain private and confidential information or material which may be privileged. If this message has come to you in error you must delete it immediately and should not copy it or show it to any other person.

From: James Cross [<mailto:James.Cross@arun.gov.uk>]

Sent: 16 January 2020 15:50

To: Emma Jones [REDACTED]

Subject: FW: RE: Y/114/19/DOC - Cinders Lane Nursey and Works to the Rear

Hi Emma,

I've received the below correspondence from our Environmental Health Officers. Could you please address these as soon as possible so we are able to work towards discharge of this condition please?

Kindest regards,

James Cross Bsc (Hons) MSc Lcgi TP. MRTPI

Senior Planning Officer

Arun District Council, Maltravers Road, Littlehampton, BN17 5LF

Email: james.cross@arun.gov.uk | DD: 01903 737784

From: Kate Giddings <kate.giddings@arun.gov.uk>

Sent: 16 January 2020 15:46

To: James Cross <James.Cross@arun.gov.uk>

Cc: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: FW: RE: Y/114/19/DOC - Cinders Lane Nursey and Works to the Rear

Dear James,

As Fiona is off sick today, the above DoC has been passed to me for comment re. condition 10 (contamination). This Department is not able to recommend discharge of points 3 and 4 of the condition as the contamination onsite has not been adequately addressed. As per my comments of 7 June 2019, Soils Ltd.'s Main Investigation Report (ref.: 17034/MIR, dated August 2018), identified exceedances of lead (located in WS4 at 0.15 mbgl) and several PAH's (located in WS1 at 0.35 mbgl); these locations appear to approximately correlate with TP2 and TP10, respectively. TP2 and TP10 were sampled at 0.5 mbgl which is not representative. The 2019 report states that the 2018 exceedances have now been subjected to statistical analysis which should please be made available.

The TP2 and TP10 samples were taken below Made Ground to determine if there was any noticeable leaching into the underlying natural materials (to which the answer would appear to be possibly a little in TP2 and nothing in TP10) from the overlying and surrounding materials so we can advise on removal depths, extents and mitigation/pathway considerations etc. in the proposed remediation strategy. Soils Limited accept that this was not made clear in the later 2019 report which has been revised (Note:Table 3.1 Page 10).

Soils Limited do not normally provide internal working documents and spreadsheets in either reports or submissions, but our working summary in XLS is enclosed on this one occasion purely for reference. However, this summary should be viewed in the context of being a working in-house document and neither repeated nor published as part of the planning submission. It should also be considered confidential and copyright of Soils Limited.

Furthermore, having now reviewed Soils Limited's Supplementary Investigation Report (ref.: 17926/SIR_R27, dated November 2019), please may EH comment as follows:

- it is assumed that the data presented in the first table on page 7 are the depths at which the made ground was identified; could this please be confirmed Please see updated report.
- please may Appendices B.3 and C be provided See above
- please may the applicant advise whether the Human Health Risk Assessment has been updated since the August 2015 version supplied within this submission Nothing has been updated appropriate generic guidance values since Nickel in 2015 – which was undertaken to mesh with the new sensitivity based waste criteria update.
- the Environment Agency may wish to comment on the potential risk to groundwater on and from the site and may wish to review the water monitoring data (Soils Ltd., ref.: 17034/GW, dated April 2019) Our geotechnical engineers would be happy to discuss this, in general the data from TP2 and TP10 (for example) does indicate that even from the elevated outliers identified, there is no significant leaching into local waters.
- the discovery strategy should be updated to read: *If during development, any visible contaminated or odorous material, (for example, asbestos containing material, stained soil, petrol / diesel / solvent odour, underground tanks or associated pipework) not previously identified, is found to be present at the site, no further development (unless otherwise expressly agreed in writing with the Local Planning Authority) shall be carried out until it has been fully investigated using suitably qualified independent consultant(s). The Local Planning Authority must be informed immediately of the nature and degree of the contamination present and a method statement detailing how the unsuspected contamination shall be dealt with must be prepared and submitted to the Local Planning Authority for approval in writing before being implemented.* Please see revised report

I look forward to receipt of a suitable remediation strategy and associated validation report.

Many thanks,

Kate.

Kate Giddings | Senior Technical Officer, Environmental Health, Arun District Council | Location: Arun Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF

Internal: 37586 | External: +44 (0) 1903 737586 | e-mail: kate.giddings@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Karen Boxall <Karen.Boxall@arun.gov.uk>
Sent: 16 January 2020 14:14
To: Kate Giddings <kate.giddings@arun.gov.uk>
Subject: FW: RE: Y/114/19/DOC - Cinders Lane Nursey and Works to the Rear

Hello,

Sorry, could you take a look for me

Thanks

Karen

From: James Cross <James.Cross@arun.gov.uk>
Sent: 15 January 2020 13:31
To: EH Planning Consultations [REDACTED]
Subject: RE: Y/114/19/DOC - Cinders Lane Nursey and Works to the Rear

Hi Environmental Health,

I am still outstanding a response regarding condition 10 of planning permission Y/5/17/OUT. I am in a position where I can discharge most other conditions but cannot proceed in the absence your formal comments in respect of this outstanding matter. I attach a copy of the original consent which details condition 10 for your assistance.

I look forward to hearing from you with anticipation.

Kindest regards,

James Cross Bsc (Hons) MSc Lcgi TP. MRTPI
Senior Planning Officer
Arun District Council, Maltravers Road, Littlehampton, BN17 5LF
Email: james.cross@arun.gov.uk | DD: 01903 737784

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not

provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
