

From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 07 February 2022 15:10

To: Simon Davis <Simon.Davis@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: Land East of Drove Lane Yapton BN18 0EB - Y/11/22/DOC

Planning Application: Y/11/22/DOC

Proposal: Approval of details reserved by condition imposed under ref Y/92/17/OUT relating to Condition Nos 5 - materials & finishes and 15 - external lighting.

Location: Land East of Drove Lane Yapton BN18 0EB

Dear Simon,

External Lighting (condition 15)

Having reviewed the documents entitled 'External Lighting Layout sheets 1, 2 and 3 of 4 Dwg No CIV-1-4032, 4033, 4034 Rev E' and document 'External Layout Lighting Dwg No CIV-1-4035 Rev E' (dated 11.1.2021) [produced by RSK Land development and Engineering Ltd] I can confirm the plans demonstrate that the external lighting complies with 'Obtrusive Light Limitations for Exterior Lighting Installations for Zone E2. In conjunction with comments from the Ecology department, I support that the condition may be discharged.

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk



Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

