

Sandra Edwards

From: Amanda Scholes on behalf of Planning.Responses
Sent: 27 March 2017 09:25
To: Planning Scanning
Subject: FW: Planning Consultation on Y/13/17/DOC

From: Thomas Callaway
Sent: 23 March 2017 16:11
To: Planning.Responses
Subject: RE: Planning Consultation on Y/13/17/DOC

Surface water drainage

The garden doesn't appear to have enough room for a soakaway, as 5m is required from any buildings. We would need confirmation of where the discharge pipe is ultimately discharging to. This would require a CCTV survey.

Regards

Tom Callaway

Thomas Callaway | Drainage & Coastal Engineer, Engineering Services, Arun District Council | Location: Second Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Arun is Working in Partnership with Chichester District Council

Visit our web site at www.arun.gov.uk and www.chichester.gov.uk



Save the environment - think before you print.

From: [REDACTED]
Sent: 14 March 2017 15:03
To: Thomas Callaway
Subject: Planning Consultation on Y/13/17/DOC

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION Y/13/17/DOC
NO:

Registered: 14-MAR-17
Site Address: 38 Cherry Avenue Yapton BN18 0LB

Description of Works: Application for approval of matters reserved by condition imposed under Y/57/16/HH relating to condition 3 for surface water drainage scheme.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 28th March 2017.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Richard Temple who can be contacted on telephone number [REDACTED]

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
