

**From:** Amanda Scholes on behalf of Planning.Responses  
**Sent:** 15 January 2021 09:41  
**To:** Planning Scanning  
**Subject:** FW: Large Development Hydrant Condition - Y/146/20/RES  
**Attachments:** LDHC - Y14620RES Street Buildings.docx

Amanda Scholes | Receptionist, Department, [Arun District Council](#) | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: [amanda.scholes@arun.gov.uk](mailto:amanda.scholes@arun.gov.uk)



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

**From:** Ian Stocks [REDACTED] On Behalf Of FRS Water and Access  
**Sent:** 14 January 2021 09:13  
**To:** Planning.Responses <[Planning.Responses@arun.gov.uk](mailto:Planning.Responses@arun.gov.uk)>  
**Subject:** Large Development Hydrant Condition - Y/146/20/RES

FAO: Mr S Davis

Dear Mr Davis,

Please find attached a planning condition for application no. Y/146/20/RES for the requirement of additional fire hydrant(s) for the proposed development. This is to ensure that all dwellings on the proposed site are within 150 metres of a fire hydrant for the supply of water for firefighting.


Evidence will also be required that Fire Service vehicle access meets with the requirements identified in Approved Document B Volume 1 2019 Edition: B5 Section 13, including Table 13.1 and diagram 13.1.

Regards

Ian Stocks  
Water & Access manager

Ian Stocks – Water and Access Manager  
Water and Access Office  
West Sussex Fire and Rescue Service [West Sussex County Council](#)  
Location: Bognor Fire Station, West Meads Drive, Bognor, PO21 5TB

## *Living Our Values Every Day*



---

### LEGAL DISCLAIMER

This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.

---

WEST SUSSEX COUNTY COUNCIL  
WEST SUSSEX FIRE AND RESCUE SERVICE

**HYDRANT CONDITION CONSULTATION WITH PLANNING AUTHORITY**

Date: 14/01/2021

To: Mr S Davis

From: Ian Stocks

Planning Ref: Y/146/20/RES

Address: Land at Street Buildings, North End Road, Yapton, BN18 0DT

Description: Application for approval of reserved matters for the erection of 45 dwellings pursuant to Section 73 permission Y/13/18/PL (following the grant of outline planning permission Y/49/17/OUT) (resubmission following Y/39/20/RES). This application may affect the setting of a Listed Building.

Date of visit: N/A

**RECOMMENDATION**

|            |                                            |               |                          |                   |                          |
|------------|--------------------------------------------|---------------|--------------------------|-------------------|--------------------------|
| Advice:    | <input checked="checked" type="checkbox"/> | Modification: | <input type="checkbox"/> | More Information: | <input type="checkbox"/> |
| Objection: | <input type="checkbox"/>                   | No Objection: | <input type="checkbox"/> | Refusal:          | <input type="checkbox"/> |

Total number of hydrants required: Unknown

**This application has been dealt with in accordance with the statutory obligation placed upon Fire and Rescue Service by the following act;**

***Fire and Rescue Services Act 2004  
Part 5, 38: Duty to secure water supply etc.***

- 1) *A fire and rescue authority must take all reasonable measures for securing that an adequate supply of water will be available for the authority's use in the event of fire.*

This proposal has been considered by means of desktop study, using the information and plans submitted with this application, in conjunction with other available WSCC mapping and Fire and Rescue Service information. A site visit can be arranged on request.

I refer to your consultation in respect of the above planning application and would provide the following comments:

- 1) Prior to the commencement of the development details showing the proposed location of the required fire hydrants shall be submitted to and approved in writing by the Local Planning Authority in consultation with West Sussex County Council's Fire and Rescue Service. These approvals shall not be unreasonably withheld or delayed.
- 2) Prior to the first occupation of any dwelling/unit forming part of the proposed development that they will at their own expense install the required fire hydrants (or in a phased programme if a large development) in the approved location to BS 750 standards or stored water supply and arrange for their connection to a water supply which is appropriate in terms of both pressure and volume for the purposes of firefighting.

The fire hydrant shall thereafter be maintained as part of the development by the water undertaker at the expense of the Fire and Rescue Service if adopted as part of the public mains supply (Fire Services Act 2004) or by the owner / occupier if the installation is retained as a private network.

As part of the Building Regulations 2004, adequate access for firefighting vehicles and equipment from the public highway must be available and may require additional works on or off site, particularly in very large developments. (BS5588 Part B 5) for further information please contact the Fire and Rescue Service

If a requirement for additional water supply is identified by the Fire and Rescue Service and is subsequently not supplied, there is an increased risk for the Service to control a potential fire. It is therefore recommended that the hydrant condition is implemented

*Reason: In the interests of amenity and in accordance with policy INF SP1 and TSP1 of the Arun Local Plan 2011-2031 and in accordance with The Fire & Rescue Service Act 2004.*

Ian Stocks  
Water and Access Manager

