

From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 10 December 2021 13:57
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: Y/156/21/DOC

Dear Simon,

Environmental Health is happy for condition 16 (CMP) to be discharged.

With regard to condition 25, electric vehicle charging strategy, please could the applicant provide further information to confirm whether or not the EV charging point provision complies with the Arun Parking Standards in Table 2.2. Table 2.2 states 100% of houses with a driveway or garage, and 20% of other development must have EV charging points. It is currently unclear whether this provision has been complied with from the current information.

Environmental Health is therefore not happy for Condition 25 to be discharged at this time.

Regards

Fiona Fitzgerald

Fiona Fitzgerald
Senior Environmental Health Officer
Environmental Health

T: 01903 737674
E: fiona.fitzgerald@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

Sign up to our newsletter [here](#)

