

Our Ref: North End Road, Yapton



Date: 02 September 2021

Lakesbury House,
Hiltingbury Road
Hampshire SO53 5SS

Redrow Homes,
C/O Tilly Whishaw,
Redrow Homes Unit 1 Faraday Office Park,
Rankine Road, Basingstoke,
Hampshire,
RG24 8QB

Dear Tilly,

LIGHTING DESIGN, NORTH END ROAD – ECOLOGY.

Following a review of the North End Road, Yapton Lighting Design Document (MMA Lighting Consultancy, 2021), we confirm that the proposed lighting design is acceptable with regards to the avoidance of impacts to bats from onsite lighting.

The design follows best practice in that it includes the use of rear light shields to reduce light spill onto the boundary habitats and illuminates only areas required. LED lighting is used throughout with a correlated colour temperature of 3000 kelvin which is the warmest lantern available.

Yours sincerely,

for RPS Consulting Services Ltd

Frances Morris

Senior Ecologist