



To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 11 January 2022 11:11
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Maria Tomalova <Maria.Tomalova@arun.gov.uk>
Subject: Y/183/21/DOC- Pollards Nursery Lake Lane Barnham PO22 0AD

Engineers Comments Regarding Conditions 5 and 6

The gravel surface section shows 200mm of sub-base. Rather than the 500mm shown on layout plans, please correct to be consistent.

Please can the applicant submit evidence that they have submitted an ordinary watercourse land drainage consent application.

Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



T: 01903 221374

E: laura.gibbons@arun.gov.uk

